



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Walter L. Baker, P.E.
Director

October 27, 2016

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the state of Utah's intention to reissue a Utah Pollutant Discharge Elimination System (UPDES) Permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES Permit and the Fact Sheet and Statement of Basis (including the total maximum daily loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: North Davis Sewer District
MAILING ADDRESS: 4252 West 2200 South, Syracuse, UT 84075
TELEPHONE NUMBER: (801) 825-0712
FACILITY LOCATION: 4252 West 2200 South, Syracuse, UT
UPDES PERMIT NO.: UT0021741
OUTFALLS: 001
RECEIVING WATERS: Unnamed irrigation drainage ditch thence to Farmington Bay

BACKGROUND

The North Davis Sewer District wastewater treatment plant (North Davis) is located at 4252 W. 2200 S., Syracuse, Utah. The facility is located approximately ¼ mile south of the Antelope Island Road and near the old shoreline of the Great Salt Lake. The District serves the municipalities of Clearfield, Clinton, Layton, Roy, Sunset, Syracuse and West Point; portions of unincorporated Davis and Weber Counties; Hill Air Force Base and the Freeport Center. The service area includes a total population of approximately 215,000. The facility completed upgrades and expansions in 2007 and 2016. The process and internal flows were changed from the previous permits. The facility has a design flow of 34 MGD with a peak of 65 MGD, and a storm event peak of 102 MGD.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on November 28, 2016. Written public comments can be submitted to: Daniel Griffin, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: dgriffin@utah.gov. After considering public comment the Director may execute the permit issuance, revise it or abandon it. The permit is available for public review at <http://www.deq.utah.gov/NewsNotices/notices/water/index.htm>. If internet access is not available, a copy may be obtained by calling Daniel Griffin 801-536-4387.

DWQ-2016-012821