



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

November 30, 2018

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF RENEWAL OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to issue a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	Payson City Wastewater Treatment Plant
MAILING ADDRESS:	439 West Utah Avenue
TELEPHONE NUMBER:	(801) 465-5277
FACILITY LOCATION:	1062 North Main
UPDES PERMIT NO.:	UT0020427
OUTFALLS:	001
RECEIVING WATERS:	Irrigation ditch to Beer Creek through Benjamin Slough to Utah Lake

BACKGROUND

The Payson City Wastewater Treatment Plant (Payson City) is located at 1062 North Main, Payson, Utah and serves the City of Payson. The design flow of the facility is 3.0 MGD average daily flow with a peak flow of 4.5 MGD. Payson City effluent is also utilized by an effluent reuse system as cooling water in a neighboring power plant.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **December 31, 2018**. Written public comments can be submitted to: Daniel Griffin, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: dgriffin@utah.gov. After considering public comment the Utah Division of Water Quality may issue, revise, or abandon the permit. The permit is available for public review under <https://deq.utah.gov/water-quality/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Daniel Griffin at 801-536-4387.

DWQ-2018-008591