

**FACT SHEET AND STATEMENT OF BASIS
PAYSON CITY WASTEWATER TREATMENT PLANT RENEWAL PERMIT:
DISCHARGE, BIOSOLIDS & STORM WATER
UPDES PERMIT NUMBER: UT0020427
UPDES BIOSOLIDS PERMIT NUMBER: UTL-020427
UPDES MULTI-SECTOR STORM WATER GENERAL PERMIT NUMBER: UTR000000
MAJOR MUNICIPAL**

FACILITY CONTACTS

Person Name:	Jeff Hiatt	Person Name:	Tyler Lowe
Position:	Plant Superintendent	Position:	Operator
Facility Name:	Payson City Wastewater Treatment Plant		
Mailing Address:	439 West Utah Ave Payson City, Utah 84651		
Telephone:	(801) 465-5277		
Actual Address:	1062 North Main St.		

DESCRIPTION OF PERMIT MODIFICATIONS

Payson submitted an updated Reuse Project Plan in conjunction with questions they had regarding the renewed permit that went into effect on February 1, 2019. It was determined after the review that the plan and program was not sufficient enough to meet the requirement for Type I Reuse. As a result of this, the permit will be modified to remove Type I requirements and add Type II Requirements.

DISCHARGE

The permit Reuse requirement and limitations for Outfall 001R (Reuse) are:

Parameter	Outfall 001R Effluent Limitations ¹				
	Max Monthly Mean	Max Weekly Mean	Max Daily Average	Minimum	Maximum
BOD ₅ , mg/L	25	-	-	-	-
TSS, mg/L	25	35	-	-	-
<i>E. coli</i> , No/100mL	-	126	-	-	500
pH, Standard Units	-	-	-	6.0	9.0

SELF-MONITORING AND REPORTING REQUIREMENTS

The following reuse self-monitoring requirements are modified from the previous permit. The permit will require reports to be submitted monthly and annually, as applicable, on Discharge Monitoring Report (DMR) forms due 28 days after the end of the monitoring period.

¹ See Definitions, Part VIII, for definition of terms.

The following is a summary of the Type II reuse self-monitoring and reporting requirements.

Reuse Outfall 001R Self-Monitoring and Reporting Requirements ^{2,3}			
Parameter	Frequency	Sample Type	Units
Total Flow	Continuous	Recorder	MGD
BOD ₅	Weekly	Composite	mg/L
TSS	Weekly	Composite	mg/L
<i>E. coli</i>	Daily	Grab	No./100mL
pH	Daily	Grab	SU

PERMIT DURATION

It is recommended that this permit be effective for the remainder of the original permit's duration of five (5) years (until January 31, 2024).

Drafted by
Daniel Griffin, Discharge
Sarah Leavitt, Reuse
Utah Division of Water Quality, (801) 536-4300

PUBLIC NOTICE

Began: Month Day, Year
Ended: Month Day, Year

Comments will be received at: 195 North 1950 West
PO Box 144870
Salt Lake City, UT 84114-4870

The Public Noticed of the draft permit was published in The Daily Herald.

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12.

DWQ-2019-015291

² See Definitions, Part VIII, for definition of terms.

³ Reuse monitoring results obtained during the previous month for reuse discharges shall be summarized for each month and reported on a Monthly Operational Report, post-marked no later than the 28th day of the month following the completed reporting period.