



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Kimberly D. Shelley
Executive Director

DIVISION OF WATER QUALITY
John K. Mackey, P.E.
Director

August 16, 2023

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA).

PERMIT INFORMATION

PERMITTEE NAME: PITMAN FAMILY FARMS, INC.
FACILITY NAME: MORONI CITY PUBLIC OWNED TREATMENT WORKS
FACILITY LOCATION: 350 South 300 West, Moroni, UT 84646
MAILING ADDRESS: PO Box 308, Moroni, UT 84646
TELEPHONE NUMBER: (435) 436-8211
UPDES PERMIT NUMBER: UT0020222
PERMITTED OUTFALL: 001
OUTFALL LOCATION: Latitude 39° 30' 52" and Longitude 111° 35' 10"
RECEIVING WATER: San Pitch River

BACKGROUND

Moroni City Public Owned Treatment Works (Moroni) is a wastewater treatment facility which consists of the following unit processes: mechanical screen, primary clarifier, pre-aeration basin then to the membrane bioreactor system with UV disinfection. The sludge is pumped to two aerobic digesters and then to the solids handling facility for dewatering. The facility has been in service since 1974 with a design capacity of 1.1 MGD. The plant is owned by Moroni City, while Pitman Family Farms, Inc. operates the plant and contributes most of the plant's influent. The facility, including the permitted outfall is located at 350 West 300 South in Moroni, Sanpete County, Utah.

PUBLIC COMMENTS

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12. Public comments are invited any time prior to the deadline of the close of business on **September 18, 2023**. Written public comments can be submitted to: Jennifer Berjikian, UPDES Individual Permits Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: wqcomments@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under “Public Notices” at <https://deq.utah.gov/division-water-quality>. If internet access is not available, a copy may be obtained by calling Jennifer Berjikian at 385-341-0272.