



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

July 24, 2018

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF REISSUANCE OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the state of Utah's intention to renew a Utah Pollutant Discharge Elimination System (UPDES) Permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES Permit and the Fact Sheet and Statement of Basis (including the total maximum daily loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	Price River Water Improvement District
MAILING ADDRESS:	PO Box 903, Price, UT 84501
TELEPHONE NUMBER:	(435) 637-6350
FACILITY LOCATION:	265 South Fairground Road, UT 84501.
UPDES PERMIT NO.:	UT0021814
OUTFALLS:	001
RECEIVING WATERS:	Price River

BACKGROUND

Price River Water Improvement District (PRWID) owns and operates a wastewater treatment facility which serves the communities of Helper, Price, Wellington and the majority of residents within the Price River Valley.

PRWID Wastewater Treatment Plant has an average effluent flow of 1.7 MGD. The treatment consists of screens, aerated grit chamber, pista-grit removal system, 2 rectangular primary clarifiers, 2 rock media trickling filters, 2 solids contact floc formation basins, 2 activated sludge aeration basins, 2 circular clarifiers, chlorine contact chamber followed by dechlorination with SO₂.

PRWID applies Class B biosolids on its on-farm operation where feed for non-dairy cattle and horses is grown.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **August 23, 2018**. Written public comments can be submitted to: Matthew Garn, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: mgarn@utah.gov. After considering public comment the Director may execute the permit issuance, revise it or abandon it. The permit is available for public review at <https://deq.utah.gov/public-notices-archive/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Matthew Garn at 801-536-4381.

195 North 1950 West • Salt Lake City, UT
Mailing Address: P.O. Box 144870 • Salt Lake City, UT 84114-4870
Telephone (801) 536-4300 • Fax (801) 536-4301 • T.D.D. (801) 536-4284
www.deq.utah.gov

Printed on 100% recycled paper