



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Scott Baird
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

November 26, 2019

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO MODIFY A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to modify a Utah Pollution Discharge Elimination System (UPDES) Permit under authority of the Utah Water Pollution Control Act, Section 19-5-104(9) and 107(2), Utah Code Annotated 1953, as amended. Said "permit" refers to the UPDES Permit and the Fact Sheet Statement of Basis (including Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303(d) of the Federal Clean Water Act (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: South Davis Sewer District-North Plant
MAILING ADDRESS: PO Box 140111, Salt Lake City, UT 84114
TELEPHONE NUMBER: 801-295-3469
FACILITY LOCATION: 1800 W 1200 North, West Bountiful, UT 84087
UPDES PERMIT NO.: UT0021636
PERMITTED OUTFALLS: 001
RECEIVING WATER: State Canal (tributary to Great Salt Lake)

BACKGROUND

The South Davis County Sewer District North Wastewater Treatment Plant (SDSDN) serves the cities of Centerville, Woods Cross, West Bountiful and portions of Bountiful with a daily average design flow of 12 million gallons per day (MGD) and a design population equivalent of 75,000. The Department of Water Quality adopted UAC R317-1-3.3, Technology-Based Phosphorus Effluent Limit (TBPEL) Rule in 2014. The TBPEL requires that all non-lagoon wastewater treatment works discharging wastewater to surface waters of the state provide treatment processes which would produce effluent less than or equal to an annual mean of 1.0 mg/L for total phosphorus. This TBPEL shall be achieved by January 1, 2020, unless facility was granted a permit variance or existing Total Maximum Daily Load (TMDL). This permit modification addresses the above rule. All other permit conditions remain unchanged.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **December 26, 2019**. Written public comments can be submitted to: Leanna Littler, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: lnlittler@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it or abandon it. The permit is available for public review under <https://deq.utah.gov/public-notices-archive/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Leanna Littler at 801-536-4397.

DWQ-2019-017080