

Official Draft Public Notice Version **November 23, 2019**  
The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

**FACT SHEET STATEMENT OF BASIS  
SOUTH DAVIS SEWER DISTRICT SOUTH TREATMENT PLANT  
PERMIT MODIFICATION  
UPDES PERMIT NUMBER: UT0021628  
MAJOR MUNICIPAL FACILITY**

**FACILITY CONTACTS**

Contact: Dal D. Wayment, P.E., General Manager  
(801) 295-3469

Mailing Address: PO Box 140111  
Salt Lake City, UT 84114-4870

Facility Address: 1800 West 1200 North  
West Bountiful, UT 84087

**DESCRIPTION OF PERMIT MODIFICATION**

The Department of Water Quality adopted UAC *R317-1-3.3, Technology-Based Phosphorus Effluent Limit (TBPEL)* Rule in 2014. The TBPEL requires that all non-lagoon wastewater treatment works discharging wastewater to surface waters of the state provide treatment processes which would produce effluent less than or equal to an annual mean of 1.0 mg/L for total phosphorus. This TBPEL shall be achieved by January 1, 2020, unless facility was granted a permit variance or existing Total Maximum Daily Load (TMDL). This permit modification addresses the above rule.

Parameter	Effluent Limitation Changes	
	Old Annual Average	New Annual Average Effective January 1, 2020
Total Phosphorous, mg/L	No Limit	1.0

**PERMIT DURATION**

It is recommended that this permit modification be effective through the current permit expiration date, November 30, 2021.

Drafted by  
Leanna Littler  
Environmental Scientist  
Utah Division of Water Quality  
(801) 536-4397

## **PUBLIC NOTICE**

Began: Month Day, Year

Ended: Month Day, Year

Comments will be received at: 195 North 1950 West  
PO Box 144870  
Salt Lake City, UT 84114-4870

The Public Noticed of the draft permit was published in the (NEWSPAPER OF RECORD FOR AREA).

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12.

### **ADDENDUM TO FSSOB**

During finalization of the Permit certain dates, spelling edits and minor language corrections were completed. Due to the nature of these changes they were not considered Major and the permit is not required to be re Public Noticed.

DWQ-2019-017088