

Official Draft Public Notice Version August 1, 2022. The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

**FACT SHEET STATEMENT OF BASIS
SPRINGDALE WASTEWATER LAGOONS
MODIFIED PERMIT: DISCHARGE
UPDES PERMIT NUMBER: UT0025224
MINOR MUNICIPAL**

FACILITY CONTACT

Person Name: Barbara Bruno
Position: Mayor
Person Name: Rick Wixom
Position: City Manager
Person Name: Robert Totten
Position: Public Works Superintendent
Phone Number: (435) 243-3686

Permittee: Town of Springdale (Springdale)
Facility Name: Springdale Wastewater Lagoons
Mailing and Facility Address: Springdale City Offices
PO Box 187
118 Lion Blvd.
Springdale, Utah 84767
Telephone: (435) 772-6907

DESCRIPTION OF PERMIT MODIFICATION

Springdale’s current UPDES Permit No. UT0025224 for the Springdale Wastewater Lagoons was issued on May 1, 2022. The permit has been modified to update the Compliance Schedule for total suspended solids (TSS) and biological oxygen demand (BOD) as a result of the Wastewater Compliance Plan submitted by Sunrise Engineering, Inc. for Springdale.

The modification is reflected below and in Part I.C.3. of the permit.

| | TSS | BOD |
|-------------------------------------|----------------------------|----------------------------|
| Date | Max. Weekly Average | Max. Weekly Average |
| Modification Issue – April 30, 2024 | 70 mg/L | 70 mg/L |
| May 1, 2024 | 65 mg/L | 65 mg/L |

PERMIT DURATION

It is recommended that this permit modification be effective until the current permit is renewed.

Drafted by
Danielle Lenz, Environmental Scientist
Utah Division of Water Quality, (801) 536-4300

PUBLIC NOTICE

Began: Month X, 2022

Ended: Month X, 2022

Comments will be received at: 195 North 1950 West
 PO Box 144870
 Salt Lake City, UT 84114-4870

The Public Notice of the draft permit was published on the Division of Water Quality webpage.

During the public comment period provided under Utah Administrative Code R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in Utah Administrative Code R317-8-6.12.

ADDENDUM TO FSSOB

RESPONSIVENESS SUMMARY

DWQ-2022-002882