



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

March 19, 2019

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to renew a Utah Pollutant Discharge Elimination System (UPDES) Permit under the authority of the Utah Water Pollution Control Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "Permit" refers to UPDES Permit and the Fact Sheet Statement Of Basis (including the Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	Stansbury Park Improvement District
MAILING ADDRESS:	# 10 Plaza, Stansbury Park, Utah 84074
TELEPHONE NUMBER:	(435) 882-7922
FACILITY LOCATION:	Stansbury Park, UT
UPDES PERMIT NO.:	UT0025241
OUTFALLS:	001, 002
RECEIVING WATERS:	unnamed ditch which flows under I-80, and hence to a playa south of the railroad, separated from the Great Salt Lake by the railroad

BACKGROUND

The Stansbury Park Improvement District's (Stansbury Park) lagoon treatment facility consists of 7 facultative cells, 2 primaries, 5 secondary and one additional emergency overflow pond. The cells are contained on 164 acres. The treatment facility was operated as a total containment treatment facility until 1996. The facility serves the City of Stansbury Park with a current population of about 8,500. The design flow was 1 MGD with operational flow of .75 MGD. The facility has completed a major upgrade to meet future demands for treatment. The upgraded final design flow is 2.7 MGD, but the limit will remain 1.5 MGD for the near future. This PN is to correct an error in the monitoring frequency of the permit for metals and total toxic organics.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **April 18, 2019**. Written public comments can be submitted to Dan Griffin, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at dgriffin@utah.gov. After considering public comment, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under <https://deq.utah.gov/water-quality/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Dan Griffin at 801-536-4387.

DWQ-2013-001715