



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of
Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

August 29, 2018

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE OF RENEWAL OF UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the state of Utah's intention to renew a Utah Pollutant Discharge Elimination System (UPDES) Permit under authority of the Utah Water Quality Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "permit" refers to UPDES Permit and the Fact Sheet and Statement of Basis (including the total maximum daily loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME: City of Tremonton
MAILING ADDRESS: 102 South Tremont Street, Tremonton, UT 84337
TELEPHONE NUMBER: 435-257-9471
FACILITY LOCATION: 300 East 1200 South, Tremonton, UT 84337
UPDES PERMIT NO.: UT0020303
PERMITTED OUTFALLS 001
RECEIVING WATER: Malad River

BACKGROUND

Tremonton Wastewater Treatment Plant (TWWTP) has a design flow rate of 2.0 million gallons per day (MGD) and currently serves the cities of Tremonton and Garland in Box Elder County, Utah. The TWWTP facility's domestic waste water flow process is as follows: influent head works with micro-screen and grit filter, a primary clarifier, two aerator basins containing four aerators each, two secondary clarifiers operated in parallel, and ultra-violet (UV) disinfection prior to any discharges. The discharging outfall into the Malad River is located on site at latitude 40° 41' 57" and longitude 112° 09' 36". The permit also includes Biosolids and Storm Water provisions as appropriate.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on September 29, 2018. Written public comments can be submitted to: Jeff Studenka, UPDES Surface Water Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: jstudenka@utah.gov. After considering public comment the Director may execute the permit issuance, revise it or abandon it. The permit is available for public review at <https://deq.utah.gov/water-quality/water-quality-public-notice>. If internet access is not available, a copy may be obtained by calling Jeff Studenka at 801-536-4395.