

**FACT SHEET AND STATEMENT OF BASIS  
TREMONTON WASTEWATER TREATMENT PLANT  
PERMIT MODIFICATION  
UPDES PERMIT NUMBER: UT0020303  
MAJOR MUNICIPAL**

**FACILITY CONTACTS**

Person Name: Paul Fulgham  
Position: Public Works Director  
Phone Number: (435) 257-9471

Facility Name: City of Tremonton  
Mailing and Facility Address: 102 South Tremont Street  
Tremonton, Utah 84337

Telephone: (435) 257-2674  
Actual Address: 300 East 1200 South  
Tremonton, Utah 84337

**DESCRIPTION OF PERMIT MODIFICATION**

The Department of Water Quality adopted UAC *R317-1-3.3, Technology-Based Phosphorus Effluent Limit (TBPEL)* Rule in 2014. The TBPEL requires that all non-lagoon wastewater treatment works discharging wastewater to surface waters of the state provide treatment processes which would produce effluent less than or equal to an annual mean of 1.0 mg/L for total phosphorus. This TBPEL shall be achieved by January 1, 2020, unless facility was granted a permit variance or existing Total Maximum Daily Load (TMDL).

DWQ is currently revising the Lower Bear River TMDL. At this point in time, there is some level of uncertainty as to what the ultimate TMDL total phosphorous (TP) allocations will be for the identified point source facilities, including TWWTP. Therefore, the total phosphorous TP monitoring requirements included in the permit addresses the TBPEL Rule. This permit may be reopened once the TMDL is finalized.

Parameter	Effluent Limitation Changes	
	Old Annual Average	New Annual Average Effective January 1, 2020
Total Phosphorous, mg/L	No Limit	1.0

## **PERMIT DURATION**

It is recommended that this permit modification be effective through the current permit expiration date, September 30, 2023.

Drafted by  
Leanna Littler  
Environmental Scientist  
Utah Division of Water Quality  
(801) 536-4397

## **PUBLIC NOTICE**

Began: Month Day, Year  
Ended: Month Day, Year

Comments will be received at: 195 North 1950 West  
PO Box 144870  
Salt Lake City, UT 84114-4870

The Public Noticed of the draft permit was published in the (NEWSPAPER OF RECORD FOR AREA).

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12.

## **ADDENDUM TO FSSOB**

During finalization of the Permit certain dates, spelling edits and minor language corrections were completed. Due to the nature of these changes they were not considered Major and the permit is not required to be re Public Noticed.

DWQ-2019-016809