



SITE NAME	DATE	Flow MGD	TSS mg/L	T-Fe mg/L	T-Se ug/L	O/G mg/L	T-Al mg/L	TDS mg/L	F-pH pH units	F-D.O. mg/L	T-Ag mg/L	T-As mg/L	T-B mg/L	T-Cd mg/L	T-Cr mg/L	T-Cu mg/L	T-Pb mg/L	T-Hg mg/L	T-Ni mg/L	T-Zn mg/L	Cyanide mg/L
UT0024368-002	11/18/2020	0.297	< 5.	0.57	< 20.	< 5.	< .02	563	8.70	9.1											
UT0024368-002	12/16/2020	0.446	< 5.	0.72	< 20.	< 5.	< .02	537	7.52	7.6	<0.020	< .01		< .02	<0.02	<0.02	< .02	<0.0002	<0.02	< .02	
UT0024368-002	1/13/2021	0.301	< 5.	0.4	< 20.	< 5.	< .02	522	8.70	10.2											
UT0024368-002	2/24/2021	0.291	< 5.	0.51	< 20.	< 5.	< .02	524	8.10	10.1											
UT0024368-002	3/24/2021	0.413	< 5.	0.59	30	< 5.	< .02	542	7.90	6.6	<0.020	0.03		< .02	<0.02	<0.02	< .02	<0.0002	<0.02	< .02	
UT0024368-002	4/28/2021	0.429	< 5.	0.73	< 20.	< 5.	< .02	507	8.20	7.9	<0.020	< .01		< .02	<0.02	<0.02	< .02	<0.0002	<0.02	< .02	
UT0024368-002	5/4/2021	0.354	< 5.	0.66	< 20.	< 5.	< .02	529	7.50	7.1											
UT0024368-002	6/9/2021	0.323	< 5.	0.63	< 20.	< 5.	< .02	514	8.30	7.4	<0.020	< .01		< .02	<0.02	<0.02	< .02	<0.0002	<0.02	< .02	
UT0024368-002	7/7/2021	0.348	< 5.	0.54	< 20.	< 5.	0.05	515	7.49	6.5											
UT0024368-002	8/9/2021	0.331	< 5.	0.55	< 20.	< 5.	< .02	515	7.33	7.1											
UT0024368-002	9/22/2021	0.331	< 5.	0.54	< 20.	< 5.	< .02	521	7.70	7.4	<0.020	< .01		< .02	<0.02	<0.02	< .02	<0.0002	<0.02	0.02	
UT0024368-002	10/14/2021	0.183	< 5.	0.79	< 20.	< 5.	< .02	528	7.22	5.9											
UT0024368-002	11/18/2021	0.119	< 5.	0.25	< 20.	< 5.	< .02	520	7.28	5.8											
UT0024368-002	12/8/2021	0.167	< 5.	0.34	< 20.	< 5.	< .02	509	8.20	6.1	<0.020	< .01		< .02	<0.02	<0.02	< .02	<0.0002	<0.02	< .02	
UT0024368-002	1/20/2022	0.112	< 5.	0.20	< 20.	< 5.	< .02	539	7.09	12.5											
UT0024368-002	2/24/2022	0.173	< 5.	0.56	< 20.	< 5.	< .02	530	7.53	10.73											
UT0024368-002	3/15/2022	0.146	< 5.	0.20	< 20.	< 5.	< .02	527	7.93	10.52	<0.020	< .01		< .02	<0.02	<0.02	< .02	<0.0002	<0.02	< .02	
	Maximum	0.757	10	1.18	160	ND	1.29	589	8.89	12.5		0.03	0.17	0.004	0.006	ND	0.02	ND	0.001	0.02	ND
	Minimum	0.112	ND	ND	ND	ND	ND	507	7.01	5.8	ND	ND	0.10	ND	ND	ND	ND	ND	ND	ND	ND
	Average	0.388	---	---	---	ND	---	541	7.88	9.18	---	---	0.14	---	---	ND	0.02	ND	---	---	---
	Reporting Lim.	---	5	0.02	20	5	0.02	30	---	---	0.02	0.01	0.02	0.02	0.02	0.02	0.02	0.0002	0.02	0.02	0.005