



State of Utah

GARY R. HERBERT
Governor

SPENCER J. COX
Lieutenant Governor

Department of Environmental Quality

Alan Matheson
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

April 6, 2019

DIVISION OF WATER QUALITY UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY PUBLIC NOTICE OF RENEWAL OF A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

The purpose of this public notice is to declare the State of Utah's intention to renew a Utah Pollutant Discharge Elimination System (UPDES) Permit under the authority of the Utah Water Pollution Control Act, Section 19-5-104 and 107, Utah Code Annotated 1953, as amended. Said "Permit" refers to UPDES Permit and the Fact Sheet Statement Of Basis (including the Total Maximum Daily Loads (TMDL's)) if applicable, as per Section 303 (d) of the Federal Clean Water Act (CWA).

PERMIT INFORMATION

PERMITTEE NAME:	City of Wellsville WWRF
MAILING ADDRESS:	75 East Main, PO Box 6, Wellsville, UT 84339
TELEPHONE NUMBER:	(435) 245-3686
FACILITY LOCATION:	Wellsville, UT
UPDES PERMIT NO.:	UT0020371
OUTFALLS:	001, 001R
RECEIVING WATERS:	Little Bear River

BACKGROUND

The City of Wellsville Water Reclamation Facility (WWRF) serves the City of Wellsville in Cache County with a population of approximately 3670 people. The facility is a four cell facultative lagoon system of 56.6 acres in size. The first cell is 15.6 acres, the second cell is 20.1 acres, the third cell is 11.2 acres and the fourth cell is 9.6 acres. Wellsville installed 75 Bio-Domes in the 3rd cell of the lagoons to enhance the removal of nutrients from the effluent. Ultraviolet disinfection is used after the final cell before discharging to the Little Bear River. They discharge at an average flowrate of 0.054MGD and have a design flow of 0.68 MGD.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **May 6, 2019**. Written public comments can be submitted to Leanna Littler, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at lnlittler@utah.gov. After considering public comment, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under <https://deq.utah.gov/water-quality/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Leanna Littler at (801) 536-4397.

DWQ-2019-001109