



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
John K. Mackey, P.E.  
Director

February 23, 2024

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO RENEW A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME: Stansbury Park Improvement District  
FACILITY NAME: Stansbury Park Improvement District Lagoons  
MAILING ADDRESS: # 10 Plaza, Stansbury Park, Utah 84074  
TELEPHONE NUMBER: (435) 882-7922  
FACILITY LOCATION: Stansbury Park, UT  
UPDES PERMIT NO.: UT0025241  
PERMITTED OUTFALLS: 001, 002  
OUTFALL LOCATION: Near LAT 40°39'30" and LONG 112°18'00" (001 and 002)  
RECEIVING WATER: Unnamed ditch to meadow wetland, then to playa area adjacent to the Great Salt Lake

**BACKGROUND**

The Stansbury Park Improvement District's lagoon treatment facility consists of 7 facultative cells, 2 primaries, 5 secondary, and one additional emergency overflow pond. The cells are contained on 164 acres. The treatment facility was operated as a total containment treatment facility until 1996. The facility serves the City of Stansbury Park, with a current population of about 8,500. The design flow was 1 MGD with an operational flow of .75 MGD. The facility has completed a major upgrade to meet future demands for treatment. The upgraded final design flow is 2.7 MGD, but the flow limit will remain 1.5 MGD for the near future.

**PUBLIC COMMENTS**

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12.

Page 2  
Public Notice

Public comments are invited any time prior to the deadline of the close of business on **March 22, 2024**. Written public comments can be submitted to: Daniel Griffin, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [wqcomments@utah.gov](mailto:wqcomments@utah.gov).

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under "Public Participation" at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Daniel Griffin at (801) 536-4387.

DWQ-2023-200384