



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
John Mackey, P.E.  
Director

April 10, 2024

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO RENEW A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME:	FAIRVIEW CITY
FACILITY NAME:	FAIRVIEW CITY WASTEWATER TREATMENT PLANT
MAILING ADDRESS:	PO BOX 97, FAIRVIEW UTAH, 84629
TELEPHONE NUMBER:	(435) 427-3858
FACILITY LOCATION:	22855 NORTH HIGHWAY 89, FAIRVIEW UTAH
UPDES PERMIT NO.:	UT0025542, UTL025542
PERMITTED OUTFALLS:	001, 001R
OUTFALL LOCATION:	LATTITUDE 39°36'23" AND LONGITUDE 111°26'50".
RECEIVING WATER:	SAN PITCH RIVER

**BACKGROUND**

Fairview City (Fairview) owns and operates the Fairview Wastewater Treatment Plant, which serves Fairview City and the surrounding area. The facility consists of screening and grit removal, an anoxic basin, an aeration basin, a membrane bioreactor (MBR), and a chlorine contact chamber. Effluent may be discharged to the San Pitch River or directed to Fairview's pressurized irrigation distribution system for Type 1 Reuse. Biosolids are stabilized in the MBR and dewatered using a belt press before being landfilled. Please refer to the draft permit documents for more information.

**PUBLIC COMMENTS**

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12.

Page 2  
Public Notice

Public comments are invited any time prior to the deadline of the close of business on **May 10, 2024**. Written public comments can be submitted to: Lonnie Shull, UPDES Individual Permits Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [lshull@utah.gov](mailto:lshull@utah.gov).

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under "Public Participation" at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Lonnie Shull at (801) 536-4393.

DWQ-2024-001062