



General Permit Construction Dewatering/Hydrostatic Testing

https://secure.utah.gov/account/login.html?returnToUrl=https%3A//secure.utah.gov/waterquality/uii_authentication

BEFORE YOU DO ANYTHING, YOU WILL NEED TO LOG IN ON THE RIGHT SIDE OF THE PAGE, BY EITHER SETTING UP A NEW ACCOUNT OR LOGGING INTO AN EXISTING ACCOUNT. This can be the same account which was used to obtain Storm Water UPDES coverage.



Once you have logged into the system, click on the top link as seen below:



**General Permit
Construction Dewatering/Hydrostatic Testing**

Once you get to this point, it is fairly easy to follow the prompts, and obtain coverage under the Construction Dewatering/ hydro testing general permit. This permit is good for one year, and can be reissued annually.

Typically Water samples are collected and analyzed once a week, or at least once during the discharge for pH, TSS and oil and Grease (if a sheen is observed) and total Residual Chlorine. Results of this analysis is due to our office by the 28th of the following month on the attached Discharge Monitoring report (DMR).

Please review the attached permit documents. It is the permittee's responsibility to be familiar with all requirements.