

Utah Division of Water Quality
Salt Lake City, Utah

WASTELOAD ANALYSIS [WLA]
Addendum: Statement of Basis

12-Jul-22
4:00 PM

Facilities: Canyon Fuel Company; SUFCO Mine
Discharging to: SUFCO_001_WLA_2022

UPDES No: UT-0022918

I. Introduction

Wasteload analyses are performed to determine point source effluent limitations necessary to maintain designated beneficial uses by evaluating projected effects of discharge concentrations on in-stream water quality. The wasteload analysis also takes into account downstream designated uses [R317-2-8, UAC]. Projected concentrations are compared to numeric water quality standards to determine acceptability. The anti-degradation policy and procedures are also considered. The primary in-stream parameters of concern may include metals (as a function of hardness), total dissolved solids (TDS), total residual chlorine (TRC), un-ionized ammonia (as a function of pH and temperature, measured and evaluated in terms of total ammonia), and dissolved oxygen.

Mathematical water quality modeling is employed to determine stream quality response to point source discharges. Models aid in the effort of anticipating stream quality at future effluent flows at critical environmental conditions (e.g., low stream flow, high temperature, high pH, etc).

The numeric criteria in this wasteload analysis may always be modified by narrative criteria and other conditions determined by staff of the Division of Water Quality.

II. Receiving Water and Stream Classification

Quitcupah Creek :	2B, 3A, 4
Antidegradation Review:	Level I review completed. Level II review required.

III. Numeric Stream Standards for Protection of Aquatic Wildlife

Total Ammonia (TNH3)	Varies as a function of Temperature and pH Rebound. See Water Quality Standards
Chronic Total Residual Chlorine (TRC)	0.011 mg/l (4 Day Average) 0.019 mg/l (1 Hour Average)
Chronic Dissolved Oxygen (DO)	6.50 mg/l (30 Day Average) 9.50 mg/l (7Day Average) 8.00 mg/l (1 Day Average)
Maximum Total Dissolved Solids	1200.0 mg/l

**Utah Division of Water Quality
Salt Lake City, Utah**

Acute and Chronic Heavy Metals (Dissolved)

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aluminum	87.00 ug/l**	0.007 lbs/day	750.00	ug/l	0.063 lbs/day
Arsenic	190.00 ug/l	0.016 lbs/day	340.00	ug/l	0.028 lbs/day
Cadmium	0.84 ug/l	0.000 lbs/day	10.07	ug/l	0.001 lbs/day
Chromium III	300.82 ug/l	0.025 lbs/day	6293.68	ug/l	0.525 lbs/day
ChromiumVI	11.00 ug/l	0.001 lbs/day	16.00	ug/l	0.001 lbs/day
Copper	34.38 ug/l	0.003 lbs/day	58.97	ug/l	0.005 lbs/day
Iron			1000.00	ug/l	0.083 lbs/day
Lead	22.21 ug/l	0.002 lbs/day	569.87	ug/l	0.048 lbs/day
Mercury	0.0120 ug/l	0.000 lbs/day	2.40	ug/l	0.000 lbs/day
Nickel	189.74 ug/l	0.016 lbs/day	1706.59	ug/l	0.142 lbs/day
Selenium	4.60 ug/l	0.000 lbs/day	20.00	ug/l	0.002 lbs/day
Silver	N/A ug/l	N/A lbs/day	52.26	ug/l	0.004 lbs/day
Zinc	436.69 ug/l	0.036 lbs/day	436.69	ug/l	0.036 lbs/day

* Allowed below discharge

**Chronic Aluminum standard applies only to waters with a pH < 7.0 and a Hardness < 50 mg/l as CaCO3

Metals Standards Based upon a Hardness of 460.13 mg/l as CaCO3

Organics [Pesticides]

Parameter	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard		
	Concentration	Load*	Concentration		Load*
Aldrin			1.500	ug/l	0.000 lbs/day
Chlordane	0.004 ug/l	0.001 lbs/day	1.200	ug/l	0.000 lbs/day
DDT, DDE	0.001 ug/l	0.000 lbs/day	0.550	ug/l	0.000 lbs/day
Dieldrin	0.002 ug/l	0.000 lbs/day	1.250	ug/l	0.000 lbs/day
Endosulfan	0.056 ug/l	0.008 lbs/day	0.110	ug/l	0.000 lbs/day
Endrin	0.002 ug/l	0.000 lbs/day	0.090	ug/l	0.000 lbs/day
Guthion			0.010	ug/l	0.000 lbs/day
Heptachlor	0.004 ug/l	0.001 lbs/day	0.260	ug/l	0.000 lbs/day
Lindane	0.080 ug/l	0.011 lbs/day	1.000	ug/l	0.000 lbs/day
Methoxychlor			0.030	ug/l	0.000 lbs/day
Mirex			0.010	ug/l	0.000 lbs/day
Parathion			0.040	ug/l	0.000 lbs/day
PCB's	0.014 ug/l	0.002 lbs/day	2.000	ug/l	0.000 lbs/day
o,p'-Dichlorophenol	13.00 ug/l	1.785 lbs/day	20.000	ug/l	0.002 lbs/day
Toxephene	0.0002 ug/l	0.000 lbs/day	0.7300	ug/l	0.000 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

IV. Numeric Stream Standards for Protection of Agriculture

	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			100.0 ug/l	lbs/day
Boron			750.0 ug/l	0.03 lbs/day
Cadmium			10.0 ug/l	0.00 lbs/day
Chromium			100.0 ug/l	lbs/day
Copper			200.0 ug/l	lbs/day
Lead			100.0 ug/l	lbs/day
Selenium			50.0 ug/l	lbs/day
TDS, Summer			1200.0 mg/l	0.05 tons/day

V. Numeric Stream Standards for Protection of Human Health (Class 1C Waters)

Metals	4 Day Average (Chronic) Standard		1 Hour Average (Acute) Standard	
	Concentration	Load*	Concentration	Load*
Arsenic			50.0 ug/l	0.007 lbs/day
Barium			1000.0 ug/l	0.137 lbs/day
Cadmium			10.0 ug/l	0.001 lbs/day
Chromium			50.0 ug/l	0.007 lbs/day
Lead			50.0 ug/l	0.007 lbs/day
Mercury			2.0 ug/l	0.000 lbs/day
Selenium			10.0 ug/l	0.001 lbs/day
Silver			50.0 ug/l	0.007 lbs/day
Fluoride (3)			1.4 ug/l	0.000 lbs/day
to			2.4 ug/l	0.000 lbs/day
Nitrates as N			10.0 ug/l	0.001 lbs/day
Chlorophenoxy Herbicides				
2,4-D			100.0 ug/l	0.014 lbs/day
2,4,5-TP			10.0 ug/l	0.001 lbs/day
Endrin			0.2 ug/l	0.000 lbs/day
hexane (Lindane)			4.0 ug/l	0.001 lbs/day
Methoxychlor			100.0 ug/l	0.014 lbs/day
Toxaphene			5.0 ug/l	0.001 lbs/day

VI. Numeric Stream Standards the Protection of Human Health from Water & Fish Consumption [Toxics]

Toxic Organics	Maximum Conc., ug/l - Acute Standards			
	Class 1C [2 Liters/Day for 70 Kg Person over 70 Yr.]		Class 3A, 3B [6.5 g for 70 Kg Person over 70 Yr.]	
Acenaphthene	1200.00 ug/l	0.16 lbs/day	2700.0 ug/l	0.37 lbs/day
Acrolein	320.00 ug/l	0.04 lbs/day	780.0 ug/l	0.11 lbs/day
Acrylonitrile	0.06 ug/l	0.00 lbs/day	0.7 ug/l	0.00 lbs/day
Benzene	1.20 ug/l	0.00 lbs/day	71.0 ug/l	0.01 lbs/day
Benzidine	0.00012 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Carbon tetrachlo	0.25 ug/l	0.00 lbs/day	4.4 ug/l	0.00 lbs/day
Chlorobenzene	680.00 ug/l	0.09 lbs/day	21000.0 ug/l	2.88 lbs/day
1,2,4-Trichlorobenzene				
Hexachlorobenze	0.00075 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Dichloroethai	0.38 ug/l	0.00 lbs/day	99.0 ug/l	0.01 lbs/day
1,1,1-Trichloroethane				
Hexachloroethan	1.90 ug/l	0.00 lbs/day	8.9 ug/l	0.00 lbs/day
1,1-Dichloroethane				
1,1,2-Trichloroeti	0.61 ug/l	0.00 lbs/day	42.0 ug/l	0.01 lbs/day
1,1,2,2-Tetrachlc	0.17 ug/l	0.00 lbs/day	11.0 ug/l	0.00 lbs/day
Chloroethane			0.0 ug/l	0.00 lbs/day
Bis(2-chloroethyl	0.03 ug/l	0.00 lbs/day	1.4 ug/l	0.00 lbs/day
2-Chloroethyl vin	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
2-Chloronaphtha	1700.00 ug/l	0.23 lbs/day	4300.0 ug/l	0.59 lbs/day
2,4,6-Trichloroph	2.10 ug/l	0.00 lbs/day	6.5 ug/l	0.00 lbs/day
p-Chloro-m-cresol			0.0 ug/l	0.00 lbs/day
Chloroform (HM)	5.70 ug/l	0.00 lbs/day	470.0 ug/l	0.06 lbs/day
2-Chlorophenol	120.00 ug/l	0.02 lbs/day	400.0 ug/l	0.05 lbs/day
1,2-Dichlorobenz	2700.00 ug/l	0.37 lbs/day	17000.0 ug/l	2.33 lbs/day
1,3-Dichlorobenz	400.00 ug/l	0.05 lbs/day	2600.0 ug/l	0.36 lbs/day
1,4-Dichlorobenz	400.00 ug/l	0.05 lbs/day	2600.0 ug/l	0.36 lbs/day
3,3'-Dichloroben:	0.04 ug/l	0.00 lbs/day	0.1 ug/l	0.00 lbs/day
1,1-Dichloroethyl	0.06 ug/l	0.00 lbs/day	3.2 ug/l	0.00 lbs/day
1,2-trans-Dichlor	700.00 ug/l	0.10 lbs/day	0.0 ug/l	0.00 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

2,4-Dichloropher	93.00 ug/l	0.01 lbs/day	790.0 ug/l	0.11 lbs/day
1,2-Dichloroprop	0.52 ug/l	0.00 lbs/day	39.0 ug/l	0.01 lbs/day
1,3-Dichloroprop	10.00 ug/l	0.00 lbs/day	1700.0 ug/l	0.23 lbs/day
2,4-Dimethylphei	540.00 ug/l	0.07 lbs/day	2300.0 ug/l	0.32 lbs/day
2,4-Dinitrotoluen	0.11 ug/l	0.00 lbs/day	9.1 ug/l	0.00 lbs/day
2,6-Dinitrotoluen	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
1,2-Diphenylhydr	0.04 ug/l	0.00 lbs/day	0.5 ug/l	0.00 lbs/day
Ethylbenzene	3100.00 ug/l	0.43 lbs/day	29000.0 ug/l	3.98 lbs/day
Fluoranthene	300.00 ug/l	0.04 lbs/day	370.0 ug/l	0.05 lbs/day
4-Chlorophenyl phenyl ether				
4-Bromophenyl phenyl ether				
Bis(2-chloroisopr	1400.00 ug/l	0.19 lbs/day	170000.0 ug/l	2.33E+01 lbs/day
Bis(2-chloroetho:	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Methylene chloric	4.70 ug/l	0.00 lbs/day	1600.0 ug/l	0.22 lbs/day
Methyl chloride (l	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Methyl bromide (0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Bromoform (HM)	4.30 ug/l	0.00 lbs/day	360.0 ug/l	0.05 lbs/day
Dichlorobromom	0.27 ug/l	0.00 lbs/day	22.0 ug/l	0.00 lbs/day
Chlorodibromom	0.41 ug/l	0.00 lbs/day	34.0 ug/l	0.00 lbs/day
Hexachlorobutad	0.44 ug/l	0.00 lbs/day	50.0 ug/l	0.01 lbs/day
Hexachlorocyclo	240.00 ug/l	0.03 lbs/day	17000.0 ug/l	2.33 lbs/day
Isophorone	8.40 ug/l	0.00 lbs/day	600.0 ug/l	0.08 lbs/day
Naphthalene				
Nitrobenzene	17.00 ug/l	0.00 lbs/day	1900.0 ug/l	0.26 lbs/day
2-Nitrophenol	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4-Nitrophenol	0.00 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
2,4-Dinitropheno	70.00 ug/l	0.01 lbs/day	14000.0 ug/l	1.92 lbs/day
4,6-Dinitro-o-cres	13.00 ug/l	0.00 lbs/day	765.0 ug/l	0.11 lbs/day
N-Nitrosodimethy	0.00069 ug/l	0.00 lbs/day	8.1 ug/l	0.00 lbs/day
N-Nitrosodipheny	5.00 ug/l	0.00 lbs/day	16.0 ug/l	0.00 lbs/day
N-Nitrosodi-n-prc	0.01 ug/l	0.00 lbs/day	1.4 ug/l	0.00 lbs/day
Pentachlorophen	0.28 ug/l	0.00 lbs/day	8.2 ug/l	0.00 lbs/day
Phenol	2.10E+04 ug/l	2.88E+00 lbs/day	4.6E+06 ug/l	6.32E+02 lbs/day
Bis(2-ethylhexyl)	1.80 ug/l	0.00 lbs/day	5.9 ug/l	0.00 lbs/day
Butyl benzyl phth	3000.00 ug/l	0.41 lbs/day	5200.0 ug/l	0.71 lbs/day
Di-n-butyl phthak	2700.00 ug/l	0.37 lbs/day	12000.0 ug/l	1.65 lbs/day
Di-n-octyl phthlate				
Diethyl phthalate	23000.00 ug/l	3.16 lbs/day	120000.0 ug/l	16.47 lbs/day
Dimethyl phthlate	3.13E+05 ug/l	4.30E+01 lbs/day	2.9E+06 ug/l	3.98E+02 lbs/day
Benzo(a)anthrac	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Benzo(a)pyrene	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Benzo(b)fluorant	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Benzo(k)fluorantl	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Chrysene (PAH)	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Acenaphthylene (PAH)				
Anthracene (PAH)	9600.00 ug/l	1.32 lbs/day	0.0 ug/l	0.00 lbs/day
Dibenzo(a,h)antf	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Indeno(1,2,3-cd)	0.0028 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Pyrene (PAH)	960.00 ug/l	0.13 lbs/day	11000.0 ug/l	1.51 lbs/day
Tetrachloroethyl	0.80 ug/l	0.00 lbs/day	8.9 ug/l	0.00 lbs/day
Toluene	6800.00 ug/l	0.93 lbs/day	200000 ug/l	27.46 lbs/day
Trichloroethylene	2.70 ug/l	0.00 lbs/day	81.0 ug/l	0.01 lbs/day
Vinyl chloride	2.00 ug/l	0.00 lbs/day	525.0 ug/l	0.07 lbs/day
			0.0	0.00 lbs/day
			0.0	0.00 lbs/day
Pesticides				
Aldrin	0.0001 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Dieldrin	0.0001 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Chlordane	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDT	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDE	0.0006 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
4,4'-DDD	0.0008 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
alpha-Endosulfar	0.9300 ug/l	0.00 lbs/day	2.0 ug/l	0.00 lbs/day
beta-Endosulfan	0.9300 ug/l	0.00 lbs/day	2.0 ug/l	0.00 lbs/day
Endosulfan sulfa	0.9300 ug/l	0.00 lbs/day	2.0 ug/l	0.00 lbs/day
Endrin	0.7600 ug/l	0.00 lbs/day	0.8 ug/l	0.00 lbs/day
Endrin aldehyde	0.7600 ug/l	0.00 lbs/day	0.8 ug/l	0.00 lbs/day
Heptachlor	0.0002 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
Heptachlor epoxide				

**Utah Division of Water Quality
Salt Lake City, Utah**

PCB's

PCB 1242 (Arocl	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1254 (Arocl	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1221 (Arocl	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1232 (Arocl	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1248 (Arocl	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1260 (Arocl	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day
PCB-1016 (Arocl	0.000044 ug/l	0.00 lbs/day	0.0 ug/l	0.00 lbs/day

Pesticide

Toxaphene	0.000750 ug/l	0.00	0.0 ug/l	0.00 lbs/day
-----------	---------------	------	----------	--------------

Dioxin

Dioxin (2,3,7,8-T	1.30E-08 ug/l	0.00 lbs/day	1.40E-08	0.00
-------------------	---------------	--------------	----------	------

Metals

Antimony	14.0 ug/l	0.00 lbs/day		
Arsenic	50.0 ug/l	0.01 lbs/day	4300.00 ug/l	0.59 lbs/day
Asbestos	7.00E+06 ug/l	9.61E+02 lbs/day		
Beryllium				
Cadmium				
Chromium (III)				
Chromium (VI)				
Copper				
Cyanide	1.30E+03 ug/l	0.18 lbs/day	2.2E+05 ug/l	30.20 lbs/day
Lead	700.0 ug/l	0.10 lbs/day		
Mercury			0.15 ug/l	0.00 lbs/day
Nickel			4600.00 ug/l	0.63 lbs/day
Selenium	0.1 ug/l	0.00 lbs/day		
Silver	610.0 ug/l	0.08 lbs/day		
Thallium			6.30 ug/l	0.00 lbs/day
Zinc				

There are additional standards that apply to this receiving water, but were not considered in this modeling/waste load allocation analysis.

VII. Mathematical Modeling of Stream Quality

Model configuration was accomplished utilizing standard modeling procedures. Data points were plotted and coefficients adjusted as required to match observed data as closely as possible.

The modeling approach used in this analysis included one or a combination of the following models.

(1) The Utah River Model, Utah Division of Water Quality, 1992. Based upon STREAMDO IV (Region VIII) and Supplemental Ammonia Toxicity Models; EPA Region VIII, Sept. 1990 and QUAL2E (EPA, Athens, GA).

(2) Utah Ammonia/Chlorine Model, Utah Division of Water Quality, 1992.

(3) AMMTOX Model, University of Colorado, Center of Limnology, and EPA Region 8

(4) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

Coefficients used in the model were based, in part, upon the following references:

(1) Rates, Constants, and Kinetics Formulations in Surface Water Quality Modeling. Environmental Research Laboratory, Office of Research and Development, U.S. Environmental Protection Agency, Athens Georgia. EPA/600/3-85/040 June 1985.

(2) Principles of Surface Water Quality Modeling and Control. Robert V. Thomann, et.al. Harper Collins Publisher, Inc. 1987, pp. 644.

**Utah Division of Water Quality
Salt Lake City, Utah**

VIII. Modeling Information

The required information for the model may include the following information for both the upstream conditions at low flow and the effluent conditions:

Flow, Q, (cfs or MGD)	D.O. mg/l
Temperature, Deg. C.	Total Residual Chlorine (TRC), mg/l
pH	Total NH3-N, mg/l
BOD5, mg/l	Total Dissolved Solids (TDS), mg/l
Metals, ug/l	Toxic Organics of Concern, ug/l

Other Conditions

In addition to the upstream and effluent conditions, the models require a variety of physical and biological coefficients and other technical information. In the process of actually establishing the permit limits for an effluent, values are used based upon the available data, model calibration, literature values, site visits and best professional judgement.

Model Inputs

The following is upstream and discharge information that was utilized as inputs for the analysis. Dry washes are considered to have an upstream flow equal to the flow of the discharge.

Current Upstream Information

	Stream Critical								
	Low Flow	Temp.	pH	T-NH3	BOD5	DO	TRC	TDS	
	cfs	Deg. C		mg/l as N	mg/l	mg/l	mg/l	mg/l	mg/l
er (Irrig. Season)	0.01	15.4	8.3	0.01	0.05	---	0.00	669.6	
Fall	0.01	4.9	8.3	0.01	0.05	---	0.00	856.4	
Winter	0.01	4.9	8.3	0.01	0.05	---	0.00	856.4	
Spring	0.01	17.6	8.2	0.01	0.05	9.33	0.00	771.5	
Dissolved	Al	As	Cd	CrIII	CrVI	Copper	Fe	Pb	
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l	
All Seasons	2.385*	0.795*	0.0795*	0.795*	3.975*	0.8*	1.25*	0.795*	
Dissolved	Hg	Ni	Se	Ag	Zn	Boron			
Metals	ug/l	ug/l	ug/l	ug/l	ug/l	ug/l			
All Seasons	0.0795*	0.795*	1.59*	0.15*	0.0795*	1.59*			* ~80% MDL

**Utah Division of Water Quality
Salt Lake City, Utah**

Projected Discharge Information

Season	Flow, MGD	Temp.
Summer	0.01000	15.8
Fall	0.01000	8.5
Winter	0.01000	8.0
Spring	0.01000	12.7

All model numerical inputs, intermediate calculations, outputs and graphs are available for discussion, inspection and copy at the Division of Water Quality.

IX. Effluent Limitations

Current State water quality standards are required to be met under a variety of conditions including in-stream flows targeted to the 7-day, 10-year low flow (R317-2-9).

Other conditions used in the modeling effort coincide with the environmental conditions expected at low stream flows.

Effluent Limitation for Flow based upon Water Quality Standards

In-stream criteria of downstream segments will be met with an effluent flow maximum value as follows:

Season	Daily Average	
Summer	0.010 MGD	0.015 cfs
Fall	0.010 MGD	0.015 cfs
Winter	0.010 MGD	0.015 cfs
Spring	0.010 MGD	0.015 cfs

Flow Requirement or Loading Requirement

The calculations in this wasteload analysis utilize the maximum effluent discharge flow of 0.01 MGD. If the discharger is allowed to have a flow greater than 0.01 MGD during 7Q10 conditions, and effluent limit concentrations as indicated, then water quality standards will be violated. In order to prevent this from occurring, the permit writers must include the discharge flow limitation as indicated above; or, include loading effluent limits in the permit.

Effluent Limitation for Whole Effluent Toxicity (WET) based upon WET Policy

Effluent Toxicity will not occur in downstream segments if the values below are met.

WET Requirements	LC50 >	100.0% Effluent	[Acute]
	IC25 >	60.7% Effluent	[Chronic]

**Utah Division of Water Quality
Salt Lake City, Utah**

Effluent Limitation for Dissolved Oxygen (DO) based upon Water Quality Standards

In-stream criteria of downstream segments for Dissolved Oxygen will be met with an effluent D.O. limitation as follows:

Season	Concentration
Summer	6.50
Fall	6.50
Winter	6.50
Spring	6.50

Effluent Limitation for Total Ammonia based upon Water Quality Standards

In-stream criteria of downstream segments for Total Ammonia will be met with an effluent limitation (expressed as Total Ammonia as N) as follows:

Season		Concentration	Load
Summer	4 Day Avg. - Chronic	6.63 mg/l as N	0.6 lbs/day
	1 Hour Avg. - Acute	9.8 mg/l as N	0.8 lbs/day
Fall	4 Day Avg. - Chronic	6.0 mg/l as N	0.5 lbs/day
	1 Hour Avg. - Acute	8.3 mg/l as N	0.7 lbs/day
Winter	4 Day Avg. - Chronic	6.4 mg/l as N	0.5 lbs/day
	1 Hour Avg. - Acute	9.3 mg/l as N	0.8 lbs/day
Spring	4 Day Avg. - Chronic	6.6 mg/l as N	0.6 lbs/day
	1 Hour Avg. - Acute	9.7 mg/l as N	0.8 lbs/day

Acute limit calculated with an Acute Zone of Initial Dilution (ZID) to be equal to 100.%.

**Utah Division of Water Quality
Salt Lake City, Utah**

**Effluent Limitations for Organics [Pesticides]
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Organics [Pesticides] will be met with an effluent limit as follows:

	4 Day Average		1 Hour Average		
	Concentration	Load	Concentration		Load
Aldrin			1.5E+00	ug/l	1.93E-04 lbs/day
Chlordane	4.30E-03 ug/l	3.59E-04 lbs/day	1.2E+00	ug/l	1.55E-04 lbs/day
DDT, DDE	1.00E-03 ug/l	8.34E-05 lbs/day	5.5E-01	ug/l	7.09E-05 lbs/day
Dieldrin	1.90E-03 ug/l	1.58E-04 lbs/day	1.3E+00	ug/l	1.61E-04 lbs/day
Endosulfan	5.60E-02 ug/l	4.67E-03 lbs/day	1.1E-01	ug/l	1.42E-05 lbs/day
Endrin	2.30E-03 ug/l	1.92E-04 lbs/day	9.0E-02	ug/l	1.16E-05 lbs/day
Guthion	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	1.29E-06 lbs/day
Heptachlor	3.80E-03 ug/l	3.17E-04 lbs/day	2.6E-01	ug/l	3.35E-05 lbs/day
Lindane	8.00E-02 ug/l	6.67E-03 lbs/day	1.0E+00	ug/l	1.29E-04 lbs/day
Methoxychlor	0.00E+00 ug/l	0.00E+00 lbs/day	3.0E-02	ug/l	3.87E-06 lbs/day
Mirex	0.00E+00 ug/l	0.00E+00 lbs/day	1.0E-02	ug/l	1.29E-06 lbs/day
Parathion	0.00E+00 ug/l	0.00E+00 lbs/day	4.0E-02	ug/l	5.16E-06 lbs/day
PCB's	1.40E-02 ug/l	1.17E-03 lbs/day	2.0E+00	ug/l	2.58E-04 lbs/day
o,p'-Dichlorophenol	1.30E+01 ug/l	1.08E+00 lbs/day	2.0E+01	ug/l	2.58E-03 lbs/day
Toxephene	2.00E-04 ug/l	1.67E-05 lbs/day	7.3E-01	ug/l	9.42E-05 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

**Effluent Targets for Pollution Indicators
Based upon Water Quality Standards**

In-stream criteria of downstream segments for Pollution Indicators will be met with an effluent limit as follows:

	Concentration	1 Hour Average Loading
Gross Beta (pCi/l)	50.0 pCi/L	
BOD (mg/l)	5.0 mg/l	0.4 lbs/day
Nitrates as N	4.0 mg/l	0.3 lbs/day
Total Phosphorus as P	0.05 mg/l	0.0 lbs/day
Total Suspended Solids	90.0 mg/l	7.5 lbs/day

Note: Pollution indicator targets are for information purposes only.

**Effluent Limitations for Protection of Human Health [Toxics Rule]
Based upon Water Quality Standards (Most stringent of 1C or 3A & 3B as appropriate.)**

In-stream criteria of downstream segments for Protection of Human Health [Toxics] will be met with an effluent limit as follows:

	Concentration	Maximum Concentration Load
Toxic Organics		
Acenaphthene	1.98E+03 ug/l	1.65E-01 lbs/day
Acrolein	5.27E+02 ug/l	4.39E-02 lbs/day
Acrylonitrile	9.71E-02 ug/l	8.10E-06 lbs/day
Benzene	1.98E+00 ug/l	1.65E-04 lbs/day
Benzidine	ug/l	lbs/day
Carbon tetrachloride	4.12E-01 ug/l	3.43E-05 lbs/day
Chlorobenzene	1.12E+03 ug/l	9.34E-02 lbs/day
1,2,4-Trichlorobenzene		
Hexachlorobenzene	1.23E-03 ug/l	1.03E-07 lbs/day
1,2-Dichloroethane	6.26E-01 ug/l	5.22E-05 lbs/day
1,1,1-Trichloroethane		
Hexachloroethane	3.13E+00 ug/l	2.61E-04 lbs/day
1,1-Dichloroethane		
1,1,2-Trichloroethane	1.00E+00 ug/l	8.37E-05 lbs/day
1,1,2,2-Tetrachloroethane	2.80E-01 ug/l	2.33E-05 lbs/day
Chloroethane		
Bis(2-chloroethyl) ether	5.10E-02 ug/l	4.26E-06 lbs/day
2-Chloroethyl vinyl ether		
2-Chloronaphthalene	2.80E+03 ug/l	2.33E-01 lbs/day
2,4,6-Trichlorophenol	3.46E+00 ug/l	2.88E-04 lbs/day
p-Chloro-m-cresol		
Chloroform (HM)	9.38E+00 ug/l	7.83E-04 lbs/day
2-Chlorophenol	1.98E+02 ug/l	1.65E-02 lbs/day
1,2-Dichlorobenzene	4.45E+03 ug/l	3.71E-01 lbs/day
1,3-Dichlorobenzene	6.59E+02 ug/l	5.49E-02 lbs/day
1,4-Dichlorobenzene	6.59E+02 ug/l	5.49E-02 lbs/day
3,3'-Dichlorobenzidine	6.59E-02 ug/l	5.49E-06 lbs/day
1,1-Dichloroethylene	9.38E-02 ug/l	7.83E-06 lbs/day
1,2-trans-Dichloroethylene1		
2,4-Dichlorophenol	1.53E+02 ug/l	1.28E-02 lbs/day
1,2-Dichloropropane	8.56E-01 ug/l	7.14E-05 lbs/day
1,3-Dichloropropylene	1.65E+01 ug/l	1.37E-03 lbs/day
2,4-Dimethylphenol	8.89E+02 ug/l	7.41E-02 lbs/day
2,4-Dinitrotoluene	1.81E-01 ug/l	1.51E-05 lbs/day
2,6-Dinitrotoluene		
1,2-Diphenylhydrazine	6.59E-02 ug/l	5.49E-06 lbs/day
Ethylbenzene	5.10E+03 ug/l	4.26E-01 lbs/day
Fluoranthene	4.94E+02 ug/l	4.12E-02 lbs/day
4-Chlorophenyl phenyl ether		
4-Bromophenyl phenyl ether		
Bis(2-chloroisopropyl) ether	2.30E+03 ug/l	1.92E-01 lbs/day
Bis(2-chloroethoxy) methane		
Methylene chloride (HM)	7.74E+00 ug/l	6.45E-04 lbs/day
Methyl chloride (HM)		

**Utah Division of Water Quality
Salt Lake City, Utah**

Methyl bromide (HM)		
Bromoform (HM)	7.08E+00 ug/l	5.90E-04 lbs/day
Dichlorobromomethane(HM)	4.45E-01 ug/l	3.71E-05 lbs/day
Chlorodibromomethane (HM)	6.75E-01 ug/l	5.63E-05 lbs/day
Hexachlorocyclopentadiene	3.95E+02 ug/l	3.29E-02 lbs/day
Isophorone	1.38E+01 ug/l	1.15E-03 lbs/day
Naphthalene		
Nitrobenzene	2.80E+01 ug/l	2.33E-03 lbs/day
2-Nitrophenol		
4-Nitrophenol		
2,4-Dinitrophenol	1.15E+02 ug/l	9.61E-03 lbs/day
4,6-Dinitro-o-cresol	2.14E+01 ug/l	1.78E-03 lbs/day
N-Nitrosodimethylamine	1.14E-03 ug/l	9.47E-08 lbs/day
N-Nitrosodiphenylamine	8.23E+00 ug/l	6.86E-04 lbs/day
N-Nitrosodi-n-propylamine	8.23E-03 ug/l	6.86E-07 lbs/day
Pentachlorophenol	4.61E-01 ug/l	3.84E-05 lbs/day
Phenol	3.46E+04 ug/l	2.88E+00 lbs/day
Bis(2-ethylhexyl)phthalate	2.96E+00 ug/l	2.47E-04 lbs/day
Butyl benzyl phthalate	4.94E+03 ug/l	4.12E-01 lbs/day
Di-n-butyl phthalate	4.45E+03 ug/l	3.71E-01 lbs/day
Di-n-octyl phthalate		
Diethyl phthalate	3.79E+04 ug/l	3.16E+00 lbs/day
Dimethyl phthalate	5.15E+05 ug/l	4.30E+01 lbs/day
Benzo(a)anthracene (PAH)	4.61E-03 ug/l	3.84E-07 lbs/day
Benzo(a)pyrene (PAH)	4.61E-03 ug/l	3.84E-07 lbs/day
Benzo(b)fluoranthene (PAH)	4.61E-03 ug/l	3.84E-07 lbs/day
Benzo(k)fluoranthene (PAH)	4.61E-03 ug/l	3.84E-07 lbs/day
Chrysene (PAH)	4.61E-03 ug/l	3.84E-07 lbs/day
Acenaphthylene (PAH)		
Anthracene (PAH)		
Dibenzo(a,h)anthracene (PAH)	4.61E-03 ug/l	3.84E-07 lbs/day
Indeno(1,2,3-cd)pyrene (PAH)	4.61E-03 ug/l	3.84E-07 lbs/day
Pyrene (PAH)	1.58E+03 ug/l	1.32E-01 lbs/day
Tetrachloroethylene	1.32E+00 ug/l	1.10E-04 lbs/day
Toluene	1.12E+04 ug/l	9.34E-01 lbs/day
Trichloroethylene	4.45E+00 ug/l	3.71E-04 lbs/day
Vinyl chloride	3.29E+00 ug/l	2.75E-04 lbs/day
Pesticides		
Aldrin	2.14E-04 ug/l	1.78E-08 lbs/day
Dieldrin	2.30E-04 ug/l	1.92E-08 lbs/day
Chlordane	9.38E-04 ug/l	7.83E-08 lbs/day
4,4'-DDT	9.71E-04 ug/l	8.10E-08 lbs/day
4,4'-DDE	9.71E-04 ug/l	8.10E-08 lbs/day
4,4'-DDD	1.37E-03 ug/l	1.14E-07 lbs/day
alpha-Endosulfan	1.53E+00 ug/l	1.28E-04 lbs/day
beta-Endosulfan	1.53E+00 ug/l	1.28E-04 lbs/day
Endosulfan sulfate	1.53E+00 ug/l	1.28E-04 lbs/day
Endrin	1.25E+00 ug/l	1.04E-04 lbs/day
Endrin aldehyde	1.25E+00 ug/l	1.04E-04 lbs/day
Heptachlor	3.46E-04 ug/l	2.88E-08 lbs/day
Heptachlor epoxide		
PCB's		
PCB 1242 (Arochlor 1242)	7.24E-05 ug/l	6.04E-09 lbs/day
PCB-1254 (Arochlor 1254)	7.24E-05 ug/l	6.04E-09 lbs/day
PCB-1221 (Arochlor 1221)	7.24E-05 ug/l	6.04E-09 lbs/day
PCB-1232 (Arochlor 1232)	7.24E-05 ug/l	6.04E-09 lbs/day
PCB-1248 (Arochlor 1248)	7.24E-05 ug/l	6.04E-09 lbs/day
PCB-1260 (Arochlor 1260)	7.24E-05 ug/l	6.04E-09 lbs/day
PCB-1016 (Arochlor 1016)	7.24E-05 ug/l	6.04E-09 lbs/day
Pesticide		
Toxaphene	1.20E-03 ug/l	1.00E-07 lbs/day

**Utah Division of Water Quality
Salt Lake City, Utah**

Metals

Antimony	23.05 ug/l	0.00 lbs/day
Arsenic	81.81 ug/l	0.01 lbs/day
Asbestos	1.15E+07 ug/l	9.61E+02 lbs/day
Beryllium		
Cadmium		
Chromium (III)		
Chromium (VI)		
Copper	2140.34 ug/l	0.18 lbs/day
Cyanide	1152.49 ug/l	0.10 lbs/day
Lead	0.00	0.00
Mercury	0.18 ug/l	0.00 lbs/day
Nickel	1004.31 ug/l	0.08 lbs/day
Selenium	0.00	0.00
Silver	0.00	0.00
Thallium	2.80 ug/l	0.00 lbs/day
Zinc		

Dioxin

Dioxin (2,3,7,8-TCDD)	2.14E-08 ug/l	1.78E-12 lbs/day
-----------------------	---------------	------------------

**Metals Effluent Limitations for Protection of All Beneficial Uses
Based upon Water Quality Standards and Toxics Rule**

	Class 4 Acute Agricultural ug/l	Class 3 Acute Aquatic Wildlife ug/l	Acute Toxics Drinking Water Source ug/l	Acute Toxics Wildlife ug/l	1C Acute Health Criteria ug/l	Acute Most Stringent ug/l	Class 3 Chronic Aquatic Wildlife ug/l
Aluminum		1233.3				1233.3	N/A
Antimony			23.0	7079.6		23.0	
Arsenic	164.6	559.3	81.8			81.8	312.3
Barium					1646.4	1646.4	
Beryllium						0.0	
Cadmium	16.4	16.5				16.4	1.3
Chromium (III)		10361.5				10361.5	494.8
Chromium (VI)	164.1	23.8				23.77	15.54
Copper	328.8	96.6	2140.3			96.6	56.1
Cyanide		36.2	362210.7			36.2	8.6
Iron		25.5				25.5	
Lead	164.1	937.7				164.1	36.0
Mercury		3.90	0.2	0.25		0.18	-0.032
Nickel		2809.2	1004.3	7573.5		1004.3	311.9
Selenium	81.3	31.9				31.9	6.5
Silver		86.0				86.0	
Thallium			2.8	10.4		2.8	
Zinc		718.9				718.9	718.9
Boron	1234.8					1234.8	
Sulfate	3292.8					3292.8	

**Utah Division of Water Quality
Salt Lake City, Utah**

Summary Effluent Limitations for Metals [Wasteload Allocation, TMDL]

[If Acute is more stringent than Chronic, then the Chronic takes on the Acute value.]

	WLA Acute ug/l	WLA Chronic ug/l	
Aluminum	1233.3	N/A	
Antimony	23.05		
Arsenic	81.8	312.3	Acute Controls
Asbestos	1.15E+07		
Barium			
Beryllium			
Cadmium	16.4	1.3	
Chromium (III)	10361.5	495	
Chromium (VI)	23.8	15.5	
Copper	96.6	56.1	
Cyanide	36.2	8.6	
Iron	25.5		
Lead	164.1	36.0	
Mercury	0.179	-0.032	
Nickel	1004.3	312	
Selenium	31.9	6.5	
Silver	86.0	N/A	
Thallium	2.8		
Zinc	718.9	718.9	
Boron	1234.81		
Sulfate	3292.8		N/A at this Waterbody

Other Effluent Limitations are based upon R317-1.

E. coli 126.0 organisms per 100 ml

X. Antidegradation Considerations

The Utah Antidegradation Policy allows for degradation of existing quality where it is determined that such lowering of water quality is necessary to accommodate important economic or social development in the area in which the waters are protected [R317-2-3]. It has been determined that certain chemical parameters introduced by this discharge will cause an increase of the concentration of said parameters in the receiving waters. Under no conditions will the increase in concentration be allowed to interfere with existing instream water uses.

An Antidegradation Level I Review was conducted on this discharge and its effect on the receiving water. Based upon that review, it has been determined that an Antidegradation Level II Review is required. The proposed permit is an increase in flow or concentration over that which was approved in the previous permit.

XI. Colorado River Salinity Forum Considerations

Discharges in the Colorado River Basin are required to have their discharge at a TDS loading of less than 1.00 tons/day unless certain exemptions apply. Refer to the Forum's Guidelines for additional information allowing for an exceedence of this value.

This doesn't apply to facilities that do not discharge to the Colorado River Basin.

XII. Summary Comments

The mathematical modeling and best professional judgement indicate that violations of receiving water beneficial uses with their associated water quality standards, including important downstream segments, will not occur for the evaluated parameters of concern as discussed above if the effluent limitations indicated above are met.