



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
Erica Brown Gaddis, PhD  
Director

**March 30, 2021**

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE OF MODIFICATION OF UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO ISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE STATEMENT OF BASIS, INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S), IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME: City of Corrine  
MAILING ADDRESS: 2420 North 4000 West  
PO Box 118  
Corinne, Utah 84307  
TELEPHONE NUMBER: 435.744.5566  
FACILITY LOCATION: ½ mile south of Corinne in Box Elder County  
UPDES PERMIT NO.: UT0020931  
PERMITTED OUTFALLS: 001 and 001D  
RECEIVING WATERS: Bear River

**BACKGROUND**

The Corinne Wastewater Lagoon System (Corinne) was constructed in 1971 with seven cells. In 1981 it was expanded to eight cells. The facility serves Corinne City with a current population of 730 people (2020 UPDES permit application). The facility consists of a bar screen, 45° V-notch inlet weir, comminutor, sump and pump station, eight facultative lagoons operating in a series, a Steven discharge flow recorder and a gas chlorine system. The lagoon has a hydraulic detention time of 180 days.

The facility has two discharge Outfalls. Outfall 001 is a ten-inch diameter concrete pipe that runs approximately 200 feet and discharges directly into the Bear River. Outfall 001D discharges into a retention ditch and then into holding ponds on the adjacent farmer's property which is used for irrigation during the growing season. The land application site is approximately 260 acres, located south and southwest west of the wastewater lagoons. The facility discharges approximately 70,000 gpd.

**PUBLIC COMMENTS**

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12. Public

comments are invited any time prior to the deadline of the close of business on **April 30, 2021**. Written public comments can be submitted to: Sarah Ward, Individual Permitting Section, Utah Division of Water Quality, P.O. Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [sarahward@utah.gov](mailto:sarahward@utah.gov). After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under “Public Notices” at <http://deq.utah.gov/water-quality/water-quality-public-notices>. If internet access is not available, a copy may be obtained by calling Sarah Ward at 385.332.9574.

DWQ-2021-005365