

Official Draft Public Notice Version **August 20, 2020**

The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

STATE OF UTAH
DIVISION OF WATER QUALITY
DEPARTMENT OF ENVIRONMENTAL QUALITY
SALT LAKE CITY, UTAH

UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMITS

Major Municipal Permit No. **UT0021920**

In compliance with provisions of the *Utah Water Quality Act, Title 19, Chapter 5, Utah Code Annotated ("UCA") 1953, as amended* (the "Act"),

LOGAN CITY CORPORATION

is hereby authorized to discharge from its wastewater treatment facility to receiving waters named,

SWIFT SLOUGH TO WETLANDS ASSOCIATED WITH THE CUTLER RESERVOIR

in accordance with specific limitations, outfalls, and other conditions set forth herein.

This permit shall become effective on August 1, 2020,

This permit expires at midnight on July 31, 2025,

Signed this XXth day of Month, 20XX.

Erica Brown Gaddis, PhD
Director

DWQ-2020-011108

Table of Contents

Outline	Page Number
I. DISCHARGE LIMITATIONS AND REPORTING REQUIREMENTS.....	1
A. Description of Discharge Points	1
B. Narrative Standard	1
C. Specific Limitations and Self-Monitoring Requirements	1
D. Reporting of Monitoring Results	8
II. INDUSTRIAL PRETREATMENT PROGRAM.....	9
A. Pretreatment Program Delegation.....	9
B. Program Updates.....	10
C. Annual Report.....	10
D. General and Specific Prohibitions	10
E. Categorical Standards.....	11
F. Enforcement Notice.....	11
G. Formal Action.....	11
H. Self-Monitoring and Reporting Requirements	11
III. BIOSOLIDS REQUIREMENTS.....	14
A. Biosolids Treatment and Disposal	14
IV. STORM WATER REQUIREMENTS.....	15
A. Coverage of This Section.....	15
B. Construction Storm water permit.....	15
V. MONITORING, RECORDING & GENERAL REPORTING REQUIREMENTS.....	16
A. Representative Sampling	16
B. Monitoring Procedures.....	16
C. Penalties for Tampering.....	16
D. Compliance Schedules.....	16
E. Additional Monitoring by the Permittee	16
F. Records Contents.....	16
G. Retention of Records	16
H. Twenty-four Hour Notice of Noncompliance Reporting.....	16
I. Other Noncompliance Reporting.....	17
J. Inspection and Entry	17
VI. COMPLIANCE RESPONSIBILITIES	19
A. Duty to Comply	19
B. Penalties for Violations of Permit Conditions	19
C. Need to Halt or Reduce Activity not a Defense.....	19
D. Duty to Mitigate.....	19
E. Proper Operation and Maintenance.....	19
F. Removed Substances.....	19
G. Bypass of Treatment Facilities	19
H. Upset Conditions	21
VII. GENERAL REQUIREMENTS.....	22
A. Planned Changes.....	22
B. Anticipated Noncompliance.....	22
C. Permit Actions	22
D. Duty to Reapply.....	22
E. Duty to Provide Information	22
F. Other Information.....	22
G. Signatory Requirements.....	22
H. Penalties for Falsification of Reports.....	23
I. Availability of Reports.....	23

DISCHARGE PERMIT NO. UT0021920
BIOSOLIDS PERMIT NO. UTL-0

J. Oil and Hazardous Substance Liability..... 23
K. Property Rights 23
L. Severability 23
M. Transfers..... 23
N. State or Federal Laws 24
O. Water Quality - Reopener Provision..... 24
P. Biosolids – Reopener Provision 24
Q. Toxicity Limitation - Reopener Provision 24
R. Storm Water-Reopener Provision 25
VIII. DEFINITIONS..... 26
 A. Wastewater 26

PND DRAFT

I. DISCHARGE LIMITATIONS AND REPORTING REQUIREMENTS

- A. Description of Discharge Points. The authorization to discharge wastewater provided under this part is limited to those outfalls specifically designated below as discharge locations. Discharges at any location not authorized under a UPDES permit are violations of the *Act* and may be subject to penalties under the *Act*. Knowingly discharging from an unauthorized location or failing to report an unauthorized discharge may be subject to criminal penalties as provided under the *Act*.

The Facility has 3 outfalls:

<u>Outfall Number</u>	<u>Location of Discharge Point</u>
001A	Discharge from the lagoon system, located approximately 100 yards downstream of the chlorination basin. The discharge is initially conveyed by means of an open ditch to Benson Road. During the irrigation season it is used as irrigation water on fields to the west of the facility. If not used as irrigation water, it is piped north along the east side of the road until it reaches the wetland polishing system. Latitude: 41°44'23 Longitude: -111°53'59
001B	Discharge from the lagoon system, located approximately 20 yards downstream of the chlorination basin. The discharge is initially conveyed by means of an open ditch to a ditch that runs to the west, parallel to 200 N. From there it is used as irrigation water on fields to the west of the facility. Latitude: 41°44'20 Longitude: -111°53'53"
002	Discharge from wetlands polishing treatment system to Swift Slough, which flows approximately 2.5 miles to wetlands associated with the Cutler Reservoir. The discharge is piped through a 36" HDPE pipe into Swift Slough. Latitude: 41°46'15.3" Longitude: -111°54'41.80"

- B. Narrative Standard. It shall be unlawful, and a violation of this permit, for the permittee to discharge or place any waste or other substance in such a way as will be or may become offensive such as unnatural deposits, floating debris, oil, scum, or other nuisances such as color, odor or taste, or cause conditions which produce undesirable aquatic life or which produce objectionable tastes in edible aquatic organisms; or result in concentrations or combinations of substances which produce undesirable physiological responses in desirable resident fish, or other desirable aquatic life, or undesirable human health effects, as determined by a bioassay or other tests performed in accordance with standard procedures.

C. Specific Limitations and Self-Monitoring Requirements.

1. Effective immediately, and lasting through the life of this permit, there shall be no acute or chronic toxicity in all Outfalls as defined in *Part VIII*, and determined by test procedures described in *Part I. C.4* of this permit.

Effective immediately and lasting the duration of this permit, the permittee is authorized to discharge from Outfall 001 and Outfall 002. Such discharges shall be limited and monitored by the permittee as specified below:

PART I
DISCHARGE PERMIT NO. UT0021920
WASTEWATER

Table 1. Effluent Limitations *a						
	Maximum Monthly Avg	Minimum Monthly Avg	Maximum Weekly Avg	Yearly Average	Daily Minimum	Daily Maximum
Outfall 001A and Outfall 001B *a *b						
BOD ₅ , mg/L	25	--	35		--	--
BOD ₅ Min. % Removal	85	--	--		--	--
TSS, mg/L	25	--	35		--	--
TSS Min. % Removal	85	--	--		--	--
E. coli, no./100mL	126	--	157		--	--
pH, Standard Units	--	--	--	--	6.5	9.0
Outfall 002 *a *b						
Total Flow, MGD *b *c						
Summer (Jul-Sep)	--	--	--	--	--	22
Fall (Oct-Dec)	--	--	--	--	--	21
Winter (Jan-Mar)	--	--	--	--	--	16
Spring (Apr-Jun)	--	--	--	--	--	21
BOD ₅ , mg/L *d	25	--	35	--	--	--
TSS, mg/L *d	25	--	35	--	--	--
Total Ammonia (as N), mg/L *e						
Summer (Jul-Sep)	--	--	--	--	--	9.1
Fall (Oct-Dec)	--	--	--	--	--	11.2
Winter (Jan-Mar)	--	--	--	--	--	14.4
Spring (Apr-Jun)	--	--	--	--	--	11.9
Dissolved Oxygen, mg/L						
Summer (Jul-Sep)	--	-- *e	--	--	4.0	--
Fall (Oct-Dec)	--	-- *e	--	--	4.0	--
Winter (Jan-Mar)	--	-- *e	--	--	4.0	--
Spring (Apr-Jun)	--	-- *e	--	--	4.0	--
Oil & Grease, mg/L	--	--	--	--	--	10.0
pH, Standard Units	--	--	--	--	6.5	9
Total Cyanide, µg/L	5.4	--	--	--	--	23.6
WET, Chronic Biomonitoring						
Summer (Jul-Sep)	--	--	--	--	--	IC25> 90% effluent
Fall (Oct-Dec)	--	--	--	--	--	IC25> 79% effluent
Winter (Jan-Mar)	--	--	--	--	--	IC25> 74% effluent
Spring (Apr-Jun)	--	--	--	--	--	IC25> 92% effluent

PART I
DISCHARGE PERMIT NO. UT0021920
WASTEWATER

Table 2: Self-Monitoring and Reporting Requirements *a			
Parameter	Frequency	Sample Type	Units
Outfall 001A and 001B (When being used as irrigation water during the irrigation season, April 15-October 1)			
Total Flow *b, *c	Continuous	Recorder	MGD
BOD ₅ , Influent *f	Weekly	Composite	mg/L
Effluent	Weekly	Composite	mg/L
TSS, Influent *f	Weekly	Composite	mg/L
Effluent	Weekly	Composite	mg/L
<i>E. coli</i>	Weekly	Grab	No./100mL
pH	Daily	Grab	SU
Outfall 002			
BOD ₅	Weekly	Composite	mg/L
TSS	Weekly	Composite	mg/L
Total Ammonia (as N)	Weekly	Composite	mg/L
pH	Daily	Grab	SU
DO *g	Daily	Grab	mg/L
Oil & Grease *h	When Sheen Observed	Grab	mg/L
WET – Biomonitoring *i			
Ceriodaphnia - Chronic	Quarterly	Composite	Pass/Fail
Fathead Minnows - Chronic	Quarterly	Composite	Pass/Fail
Orthophosphate (as P), Effluent	Weekly	Composite	mg/L
Total Phosphorus (as P), Influent	Weekly	Composite	mg/L
Effluent	Weekly	Composite	mg/L
Total Kjeldahl Nitrogen, TKN (as N)			
Influent	Weekly	Composite	mg/L
Effluent	Weekly	Composite	mg/L
Nitrate, NO ₃	Weekly	Composite	mg/L
Nitrite, NO ₂	Weekly	Composite	mg/L
Metals, Influent	Quarterly	Grab/Composite	mg/L
Effluent	Quarterly	Grab/Composite	mg/L
Organic Toxics, Influent	Yearly	Grab/Composite	mg/L
Effluent	Yearly	Grab/Composite	mg/L

*a See Definitions, *Part VIII*, for definition of terms.

*b Flow measurements of influent/effluent volume shall be made in such a manner that the permittee can affirmatively demonstrate that representative values are being obtained.

*c If the rate of discharge is controlled, the rate and duration of discharge shall be reported.

*d Since percent removal requirement shall already be met at Outfall 001a and Outfall 001b, no percent removal requirement will be required at outfall 002

PART I
DISCHARGE PERMIT NO. UT0021920
WASTEWATER

- *e Interim limits for the Logan City Lagoons. Final Limits for the new mechanical treatment plants are found in the compliance schedule found in *Part 1.C.3.a* of the permit and will become effective April 1, 2022 after the new mechanical plant is operational.
- *f In addition to monitoring the final discharge, influent samples shall be taken and analyzed for this constituent at the same frequency as required for this constituent in the discharge.
- *g Dissolved Oxygen: In addition to the effluent limit for daily minimum, the facility will also be required to report the monthly minimum average.
- *h Oil & Grease sampled when sheen is present or visible. If no sheen is present or visible, report NA.
- *i Both the chronic *Ceriodaphnia* and chronic fathead minnows will be tested quarterly.

2. Compliance Schedule

- a. Bear River Middle and Cutler Reservoir TMDL Compliance Schedule: The permittee shall complete the listed items (below) by the indicated dates.
- b. Monthly Minimum Dissolved Oxygen.

Date	Milestone
October 1, 2021	Logan City shall complete construction of wastewater treatment upgrades and begin startup and optimization of upgraded wastewater treatment processes.
April 1, 2022	<p>Logan City shall achieve compliance with all effluent limits prescribed in UPDES Permit # UT0021920 and Bear River Middle and Cutler Reservoir TMDL including all new phosphorus and ammonia effluent limits.</p> <p>The final phosphorus limits from outfall 002 shall be 4,405 kg/ total phosphorus from May through October and 11,831 kg total phosphorus from November through April.</p> <p>If Logan city decides to move its discharge point to Outfall 001A and/or Outfall 001B, then the final phosphorus limits from those outfalls shall be a combined total of 11,487 kg from May through October and 12,901 kg from November through April.</p> <p>Final ammonia limits at the new mechanical treatment plant shall be: 30 Day Average of 3.0 mg/L in Winter, 2.0 mg/L in Spring and Summer and 3.5 mg/L in Fall.</p> <p>Daily Maximum shall be 11.0 mg/L in Winter, 5.8 mg/L in Spring, 10.0 mg/L in Summer and 12.0 mg/L in Fall</p>
April 1, 2022	<p>Logan City shall achieve compliance with all effluent limits prescribed in UPDES Permit # UT0021920.</p> <p>Final Limits for Dissolved Oxygen, Monthly Minimum Summer, 5.0 mg/L, Fall, 4.5 mg/L, Winter 4.0 mg/L, Spring, 5.0 mg/L.</p>

3. Chronic Whole Effluent Toxicity (WET) Testing.

a. *Whole Effluent Testing – Chronic Toxicity.*

Starting on immediately, the permittee shall quarterly, conduct chronic static renewal toxicity tests on a composite sample of the final effluent at Outfall 002. The sample shall be collected at the point of compliance before mixing with the receiving water.

Three samples are required and samples shall be collected on Monday, Wednesday and Friday of each sampling period or collected on a two day progression for each sampling period. This may be changed with Director approval.

The chronic toxicity tests shall be conducted in general accordance with the procedures set out in the latest revision of *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms, Fourth Edition*, October 2002, EPA-821-R-02-013 as per 40 CFR 136.3(a) TABLE IA-LIST OF APPROVED BIOLOGICAL METHODS . Test species shall consist of *Ceriodaphnia dubia* and *Pimephales promelas* (fathead minnow). Upon approval from the Director, a carbon dioxide atmosphere may be used in order to account for pH drift once it has been demonstrated that pH drift is artificially impacting the toxicity of the sample. However, this test must be performed simultaneously with an unaltered atmosphere test and must adhere to the procedures specified in *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms, Fourth Edition. October 2002, EPA-921-R-02-013*

A multi dilution test consisting of at least five concentrations and a control is required at two dilutions below and two above the RWC, if possible. If test acceptability criteria are not met for control survival, growth, or reproduction, the test shall be considered invalid. A valid replacement test is required within the specified sampling period to remain in compliance with this permit. Chronic toxicity occurs when, during a chronic toxicity test, the 25% inhibition concentration (IC₂₅) calculated on the basis of test organism survival and growth or survival and reproduction, is less than or equal to Summer >90, Fall >79, Winter >74 and Spring >92 effluent concentration (equivalent to the RWC). If a sample is found to be chronically toxic during a routine test, the monitoring frequency shall become biweekly (see *Part I.C.4.b Accelerated Testing*). If possible, dilution water should be obtained from the receiving stream.

If the permit contains a total residual chlorine limitation such that it may interfere with WET testing (>0.20 mg/L), the permittee may dechlorinate the sample in accordance with the standard method. If dechlorination is negatively affecting the test, the permittee may collect the sample just before chlorination with Director approval.

Quarterly test results shall be reported along with the Discharge Monitoring Report (DMR) submitted for the end of the required reporting period (e.g., biomonitoring results for the calendar quarter ending March 31 shall be reported with the DMR due April 28, with the remaining biomonitoring reports submitted with DMRs due each July 28, October 28, and January 28). Monthly test results shall be reported along with the DMR submitted for that month. The format for the report shall be consistent with Appendix C of “Utah Pollutant Discharge Elimination System (UPDES) Permitting and Enforcement Guidance Document for Whole Effluent Toxicity, Utah Division of Water Quality, February, 2018.

PART I
DISCHARGE PERMIT NO. UT0021920
WASTEWATER

- b. *Accelerated Testing.* When whole effluent toxicity is indicated during routine WET testing as specified in this permit, the permittee shall notify the Director in writing within 5 days after becoming aware of the test result. The permittee shall perform an accelerated schedule of WET testing to establish whether a pattern of toxicity exists unless the permittee notifies the Director and commences a PTI, TIE, or a TRE. Accelerated testing or the PTI, TIE, or TRE will begin within fourteen days after the permittee becomes aware of the test result. Accelerated testing shall be conducted as specified under Part I. Pattern of Toxicity. If the accelerated testing demonstrates no pattern of toxicity, routine monitoring shall be resumed.
- c. *Pattern of Toxicity.* A pattern of toxicity is defined by the results of a series of up to five biomonitoring tests pursuant to the accelerated testing requirements using a full set of dilutions for acute (five plus the control) and five effluent dilutions for chronic (five plus the control), on the species found to be more sensitive, once every week for up to five consecutive weeks for acute and once every two weeks up to ten consecutive weeks for chronic. If two (2) consecutive tests (not including the scheduled test which triggered the search for a pattern of toxicity) do not result in an exceedance of the acute or chronic toxicity criteria, no further accelerated testing will be required and no pattern of toxicity will be found to exist. The permittee will provide written verification to the Director within 5 days of determining no pattern of toxicity exists, and resume routine monitoring.

A pattern of toxicity may or may not be established based on the following:

WET tests should be run at least weekly (acute) or every two weeks (chronic) (note that only one test should be run at a time), for up to 5 tests, until either:

- 1) 2 consecutive tests fail, or 3 out of 5 tests fail, at which point a pattern of toxicity will have been identified, or
- 2) 2 consecutive tests pass, or 3 out of 5 tests pass, in which case no pattern of toxicity is identified.

- d. *Preliminary Toxicity Investigation.*

- (1) When a pattern of toxicity is detected the permittee will notify the Director in writing within 5 days and begin an evaluation of the possible causes of the toxicity. The permittee will have 15 working days from demonstration of the pattern of toxicity to complete an optional Preliminary Toxicity Investigation (PTI) and submit a written report of the results to the Director. The PTI may include, but is not limited to: additional chemical and biological monitoring, examination of pretreatment program records, examination of discharge monitoring reports, a thorough review of the testing protocol, evaluation of treatment processes and chemical use, inspection of material storage and transfer areas to determine if any spill may have occurred.
- (2) If the PTI identifies a probable toxicant and/or a probable source of toxicity, the permittee shall submit, as part of its final results, written notification of that effect to the Director. Within thirty days of completing the PTI the permittee shall submit to the Director for approval a control program to control effluent toxicity and shall proceed to implement such plan in accordance with the Director's approval. The control program, as submitted to or revised by the

PART I
DISCHARGE PERMIT NO. UT0021920
WASTEWATER

Director, will be incorporated into the permit. After final implementation, the permittee must demonstrate successful removal of toxicity by passing a two species WET test as outlined in this permit. With adequate justification, the Director may extend these deadlines.

- (3) If no probable explanation for toxicity is identified in the PTI, the permittee shall notify the Director as part of its final report, along with a schedule for conducting a Phase I Toxicity Reduction Evaluation (TRE) (see *Part I.4.e Toxicity Reduction Evaluation*)
 - (4) If toxicity spontaneously disappears during the PTI, the permittee shall submit written notification to that effect to the Director, with supporting testing evidence.
- e. *Toxicity Reduction Evaluation (TRE)*. If a pattern of toxicity is detected the permittee shall initiate a TIE/TRE within 7 days unless the Director has accepted the decision to complete a PTI. With adequate justification, the Director may extend the 7-day deadline. The purpose of the TIE portion of a TRE will be to establish the cause of the toxicity, locate the source(s) of the toxicity, and the TRE will control or provide treatment for the toxicity.

A TRE may include but is not limited to one, all, or a combination of the following:

- (1) Phase I – Toxicity Characterization
- (2) Phase II – Toxicity Identification Procedures
- (3) Phase III – Toxicity Control Procedures
- (4) Any other appropriate procedures for toxicity source elimination and control.

If the TRE establishes that the toxicity cannot be immediately eliminated, the permittee shall submit a proposed compliance plan to the Director. The plan shall include the proposed approach to control toxicity and a proposed compliance schedule for achieving control. If the approach and schedule are acceptable to the Director, this permit may be reopened and modified.

If toxicity spontaneously disappears during the TIE/TRE, the permittee shall submit written notification to that effect to the Director.

If the TRE shows that the toxicity is caused by a toxicant(s) that may be controlled with specific numerical limitations, the permittee shall submit the following:

- (a) An alternative control program for compliance with the numerical requirements.
- (b) If necessary, as determined by the Director, provide a modified biomonitoring protocol which compensates for the pollutant(s) being controlled numerically.

PART I
DISCHARGE PERMIT NO. UT0021920
WASTEWATER

This permit may be reopened and modified to incorporate any additional numerical limitations, a modified compliance schedule if judged necessary by the Director, and/or modified WET testing requirements without public notice.

Failure to conduct an adequate TIE/TRE plan or program as described above, or the submittal of a plan or program judged inadequate by the Director, shall be considered a violation of this permit. After implementation of TIE/TRE plan, the permittee must demonstrate successful removal of toxicity by passing a two species WET test as outlined in this permit.

D. Reporting of Monitoring Results.

1. Reporting of Wastewater Monitoring Results Monitoring results obtained during the previous month shall be summarized for each month and reported on a Discharge Monitoring Report Form (EPA No. 3320-1)* or by NetDMR, post-marked or entered into NetDMR no later than the 28th day of the month following the completed reporting period. The first report is due on September 28, 2020. If no discharge occurs during the reporting period, "no discharge" shall be reported. Legible copies of these, and all other reports including whole effluent toxicity (WET) test reports required herein, shall be signed and certified in accordance with the requirements of *Signatory Requirements (see Part VII.G)*, and submitted by NetDMR, or to the Division of Water Quality at the following address:

Department of Environmental Quality
Division of Water Quality
PO Box 144870
Salt Lake City, Utah 84114-4870

* Starting January 1, 2017 monitoring results must be submitted using NetDMR unless the permittee has successfully petitioned for an exception.

II. INDUSTRIAL PRETREATMENT PROGRAM

- A. Pretreatment Program Delegation. The permittee has been delegated primary responsibility for enforcing against discharges prohibited by *40 CFR 403.5* and applying and enforcing any national Pretreatment Standards established by the United States Environmental Protection Agency in accordance with Section 307 (b) and (c) of *The Clean Water Act (CWA)*, as amended by *The Water Quality Act (WQA)*, of 1987.

The permittee shall implement the Industrial Pretreatment Program in accordance with the legal authorities, policies, and procedures described in the permittee's approved Pretreatment Program submission. Such program commits the permittee to do the following:

1. Carry out inspection, surveillance, and monitoring procedures, which will determine independent of information supplied by the industrial user, whether the industrial user is in compliance with the pretreatment standards. At a minimum, all significant industrial users shall be inspected and sampled by the permittee at least once per year;
2. Control through permit, order, or similar means, the contribution to the POTW by each industrial user to ensure compliance with applicable pretreatment standards and requirements;
3. Require development, as necessary, of compliance schedules by each industrial user for the installation of control technologies to meet applicable pretreatment standards;
4. Maintain and update industrial user information as necessary, to ensure that all IUs are properly permitted and/or controlled at all times;
5. Enforce all applicable pretreatment standards and requirements and obtain appropriate remedies for noncompliance by any industrial user;
6. Annually publish a list of industrial users that were determined to be in significant noncompliance during the previous year. The notice must be published before March 28 of the following year;
7. Maintain an adequate revenue structure and staffing level for continued implementation of the Pretreatment Program.
8. Evaluate all significant industrial users at least once every two years to determine if they need to develop a slug prevention plan. If a slug prevention plan is required, the permittee shall insure that the plan contains at least the minimum elements required in *40 CFR 403.8(f)(2)(v)*;
9. Notify all significant industrial users of their obligation to comply with applicable requirements under *Subtitles C and D* of the *Resource Conservation and Recovery Act (RCRA)*; and
10. Develop, implement, and maintain an enforcement response plan as required by *40 CFR 403.8(f)(5)* which shall, at a minimum,
 - a. Describe how the POTW will investigate instances of noncompliance;
 - b. Describe the types of escalating enforcement responses the POTW will take in response to all anticipated type of industrial user violations; and

PART II
DISCHARGE PERMIT NO. UT0021920
PRETREATMENT

- c. Describe the time periods within which such responses will be taken and identify the POTW staff position(s) responsible for pursuing these actions.
11. Establish and enforce specific local limits as necessary to implement the provisions of the *40 CFR Parts 403.5(a) and (b)*, and as required by *40 CFR Part 403.5(c)*.
- B. Program Updates. The permittee is required to modify its pretreatment program, as necessary, to reflect changes in the regulations of *40 CFR 403*. Such modifications shall be completed within the time frame set forth by the applicable regulations. Modification of the approved pretreatment program must be done in accordance with the requirements of *40 CFR 403.18*. Modifications of the approved program which result in less stringent industrial user requirements shall not be effective until after approval has been granted by the Director.
- C. Annual Report. The permittee shall provide the Division of Water Quality and EPA with an annual report briefly describing the permittee's pretreatment program activities over the previous calendar year. Reports shall be submitted no later than March 28 of each year. These annual reports shall, at a minimum, include:
1. An updated listing of the permittee's industrial users.
 2. A descriptive summary of the compliance activities including numbers of any major enforcement actions, i.e., administrative orders, penalties, civil actions, etc.
 3. An assessment of the compliance status of the permittee's industrial users and the effectiveness of the permittee's Pretreatment Program in meeting its needs and objectives.
 4. A summary of all sampling data taken of the influent and effluent for those pollutants listed in *Part II.H*.
 5. A description of all substantive changes made to the permittee's pretreatment program referenced in *Section B* of this section. Substantive changes include, but are not limited to, any change in any ordinance, major modification in the program's administrative structure or operating agreement(s), a significant reduction in monitoring, or a change in the method of funding the program.
 6. Other information as may be determined necessary by the Director.
- D. General and Specific Prohibitions. Pretreatment standards (*40 CFR 403.5*) specifically prohibit the introduction of the following pollutants into the waste treatment system from any source of non-domestic discharge:
1. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, wastestreams with a closed cup flashpoint of less than 140°F (60°C);
 2. Pollutants, which will cause corrosive structural damage to the POTW, but in no case, discharges with a pH lower than 5.0;
 3. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW resulting in interference;

PART II
DISCHARGE PERMIT NO. UT0021920
PRETREATMENT

4. Any pollutant, including oxygen demanding pollutants (BOD, etc.), released in a discharge at such volume or strength as to cause interference in the POTW;
 5. Heat in amounts, which will inhibit biological activity in the POTW, resulting in interference, but in no case, heat in such quantities that the influent to the sewage treatment works exceeds 104°F (40°C);
 6. Petroleum oil, nonbiodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
 7. Pollutants, which result in the presence of toxic gases, vapor, or fumes within the POTW in a quantity that may cause worker health or safety problems;
 8. Any trucked or hauled pollutants, except at discharge points designated by the POTW; or
 9. Any pollutant that causes pass through or interference at the POTW.
 10. Any specific pollutant which exceeds any local limitation established by the POTW in accordance with the requirement of *40 CFR 403.5(c)* and *40 CFR 403.5(d)*.
- E. Categorical Standards. In addition to the general and specific limitations expressed in *Part A and D* of this section, applicable National Categorical Pretreatment Standards must be met by all industrial users of the POTW. These standards are published in the federal regulations at *40 CFR 405 et. seq.*
- F. Enforcement Notice. *UCA 19-5-104* provides that the State may issue a notice to the POTW stating that a determination has been made that appropriate enforcement action must be taken against an industrial user for noncompliance with any pretreatment requirements within 30 days. The issuance of such notice shall not be construed to limit the authority of the Director.
- G. Formal Action. The Director retains the right to take legal action against any industrial user and/or POTW for those cases where a permit violation has occurred because of the failure of an industrial user to meet an applicable pretreatment standard.
- H. Self-Monitoring and Reporting Requirements.
1. Influent and Effluent Monitoring and Reporting Requirements. The permittee shall sample and analyze both the influent and effluent, for the parameters listed in the Monitoring for Pretreatment Program Table.

PART II
DISCHARGE PERMIT NO. UT0021920
PRETREATMENT

Monitoring for Pretreatment Program Table				
Parameter	MDL a*	Sample Type	Frequency	Units
Total Arsenic	0.100	Composite	Quarterly	mg/L
Total Cadmium	0.00055			
Total Chromium	0.108			
Total Copper	0.021			
Total Lead	0.0105			
Total Molybdenum	NA			
Total Nickel	0.117			
Total Selenium	0.0047			
Total Silver	0.0188			
Total Zinc	0.268			
Total Cyanide	0.0226			
Total Mercury	0.000012			
TTOs, b*	NA			

a* The minimum detection limit (MDL) of the test method used for analysis must be below this limit, if a test method is not available the permittee must submit documentation to the Director regarding the method that will be used.

b* In addition, the permittee shall analyze the treatment facility influent and effluent for the presence of the toxic pollutants listed in 40 CFR 122 Appendix D Table II (Organic Toxic Pollutants). The pesticides fraction of Appendix D, Table II is suspended unless pesticides are expected to be present.

The results of the analyses of metals, cyanide and toxic organics shall be submitted along with the Discharge Monitoring Report (DMR) at the end of the earliest possible reporting period. Also the permittee must submit a copy of the toxic organics data to the DWQ's Pretreatment Coordinator via email.

For local limit parameters it is recommended that the most sensitive method be used for analysis. This will determine if the parameter is present and provide removal efficiencies based on actual data rather than literature values. If a parameter load is greater than the allowable head works load, for any pollutant listed in Part II.H.1. or a pollutant of concern listed in the local limit development document, the permittee must report the exceedances to the DWQ's Pretreatment Coordinator. If the loading exceeds the allowable headworks load, increase sampling must occur based on the requirements given by the DWQ's Pretreatment Coordinator. If needed sampling may need to occur to find the source(s) of the increase. This may include sampling of the collection system. Notification regarding the exceedances of the allowable headworks loading can be provided via email.

- In accordance with the requirements of 40 CFR Part 403.5(c), the permittee shall determine if there is a need to develop or revise its local limits in order to implement the general and specific prohibitions of 40 CFR Part 403.5 (a) and Part 403.5 (b). A technical evaluation of the need to develop or revise local limits shall be submitted to the Division within 12 months of the effective date of this permit. This evaluation should be conducted in accordance with the latest revision of the EPA Local Limits Development Guidance. If a technical evaluation, reveals that development or revision of local limits is necessary, the permittee shall submit the proposed local limits revision to the Division of

PART II
DISCHARGE PERMIT NO. UT0021920
PRETREATMENT

Water Quality for approval, and after approval implement the new local limits, within 12 months of the Division's determination that a revision is necessary.

PND DRAFT

III. BIOSOLIDS REQUIREMENTS

- A. Biosolids Treatment and Disposal. The State of Utah has adopted the *40 CFR 503* federal regulations for the disposal of sewage sludge (biosolids) by reference. However, since this facility is a lagoon, there is not any regular sludge production. Therefore *40 CFR 503* does not apply at this time. In the future, if the sludge needs to be removed from the lagoons and is disposed in some way, the Division of Water Quality must be contacted prior to the removal of the sludge to ensure that all applicable state and federal regulations are met.

PND DRAFT

IV. STORM WATER REQUIREMENTS.

- A. Coverage of This Section. The permittee is required to maintain separate coverage or an appropriate exclusion under the Multi-Sector General Permit (MSGP) for Storm Water Discharges Associated with Industrial Activities (UTR000000). This is required for all treatment works treating domestic sewage or any other sewage sludge or wastewater treatment device or system used in the storage treatment, recycling, and reclamation of municipal or domestic sewage, including land dedicated to the disposal of sewage sludge that are located within the confines of a facility with a design flow of 1.0 mgd or more, or are required to have an approved pretreatment program under *40 CFR Part 403*. Not included are farm lands, domestic gardens or lands used for sludge management where sludge is beneficially reused and that are not physically located in the confines of the facility, or areas that are in compliance with *40 CFR Part 503*. If the facility is not already covered, it has 30 days from when this permit is issued to submit the appropriate Notice of Intent (NOI) for the MSGP or exclusion documentation.
- B. Construction Storm water permit. Construction at the facility that disturbs an acre or more of land, including less than an acre if it is part of a common plan of development or sale, is required to obtain coverage under the Construction General Storm Water Permit (UTRC00000). Permit coverage must be obtained prior to land disturbance. If the site qualifies, a Low Erosivity Waiver (LEW) Certification may be submitted instead of permit coverage.

V. MONITORING, RECORDING & GENERAL REPORTING REQUIREMENTS

- A. Representative Sampling. Samples taken in compliance with the monitoring requirements established under *Part I* shall be collected from the effluent stream prior to discharge into the receiving waters. Samples and measurements shall be representative of the volume and nature of the monitored discharge. Samples of biosolids shall be collected at a location representative of the quality of biosolids immediately prior to the use-disposal practice.
- B. Monitoring Procedures. Monitoring must be conducted according to test procedures approved under *Utah Administrative Code ("UAC") R317-2-10 and 40 CFR Part 503*, unless other test procedures have been specified in this permit.
- C. Penalties for Tampering. The *Act* provides that any person who falsifies, tampers with, or knowingly renders inaccurate, any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than six months per violation, or by both.
- D. Compliance Schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any Compliance Schedule of this permit shall be submitted no later than 14 days following each schedule date.
- E. Additional Monitoring by the Permittee. If the permittee monitors any parameter more frequently than required by this permit, using test procedures approved under *UAC R317-2-10 and 40 CFR 503* or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or the Biosolids Report Form. Such increased frequency shall also be indicated. Only those parameters required by the permit need to be reported.
- F. Records Contents. Records of monitoring information shall include:
1. The date, exact place, and time of sampling or measurements;
 2. The individual(s) who performed the sampling or measurements;
 3. The date(s) and time(s) analyses were performed;
 4. The individual(s) who performed the analyses;
 5. The analytical techniques or methods used; and,
 6. The results of such analyses.
- G. Retention of Records. The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least five years from the date of the sample, measurement, report or application. This period may be extended by request of the Director at any time. A copy of this UPDES permit must be maintained on site during the duration of activity at the permitted location
- H. Twenty-four Hour Notice of Noncompliance Reporting.
1. The permittee shall (orally) report any noncompliance including transportation accidents, spills, and uncontrolled runoff from biosolids transfer or land application sites which may seriously endanger health or environment, as soon as possible, but no later than twenty-four (24) hours from the time the permittee first became aware of circumstances. The

PART V
DISCHARGE PERMIT NO. UT0021920
BIOSOLIDS PERMIT NO. UTL-0

report shall be made to the Division of Water Quality, (801) 536-4300, or 24-hour answering service (801) 536-4123.

2. The following occurrences of noncompliance shall be reported by telephone (801) 536-4300 as soon as possible but no later than 24 hours from the time the permittee becomes aware of the circumstances:
 - a. Any noncompliance which may endanger health or the environment;
 - b. Any unanticipated bypass, which exceeds any effluent limitation in the permit (See *Part VI.G, Bypass of Treatment Facilities.*);
 - c. Any upset which exceeds any effluent limitation in the permit (See *Part VI.H, Upset Conditions.*);
 - d. Violation of a daily discharge limitation for any of the pollutants listed in the permit; or,
 - e. Violation of any of the Table 3 metals limits, the pathogen limits, the vector attraction reduction limits or the management practices for biosolids that have been sold or given away.
3. A written submission shall also be provided within five days of the time that the permittee becomes aware of the circumstances. The written submission shall contain:
 - a. A description of the noncompliance and its cause;
 - b. The period of noncompliance, including exact dates and times;
 - c. The estimated time noncompliance is expected to continue if it has not been corrected;
 - d. Steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance; and,
 - e. Steps taken, if any, to mitigate the adverse impacts on the environment and human health during the noncompliance period.
4. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours by the Division of Water Quality, (801) 536-4300.
5. Reports shall be submitted to the addresses in *Part I.D, Reporting of Monitoring Results.*
- I. Other Noncompliance Reporting. Instances of noncompliance not required to be reported within 24 hours shall be reported at the time that monitoring reports for *Part I.D* are submitted. The reports shall contain the information listed in *Part V.H.3*
- J. Inspection and Entry The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by law, to:
 1. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of the permit;

PART V
DISCHARGE PERMIT NO. UT0021920
BIOSOLIDS PERMIT NO. UTL-0

2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
3. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit, including but not limited to, biosolids treatment, collection, storage facilities or area, transport vehicles and containers, and land application sites;
4. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the *Act*, any substances or parameters at any location, including, but not limited to, digested biosolids before dewatering, dewatered biosolids, biosolids transfer or staging areas, any ground or surface waters at the land application sites or biosolids, soils, or vegetation on the land application sites; and,
5. The permittee shall make the necessary arrangements with the landowner or leaseholder to obtain permission or clearance, the Director, or authorized representative, upon the presentation of credentials and other documents as may be required by law, will be permitted to enter without delay for the purposes of performing their responsibilities.

VI. COMPLIANCE RESPONSIBILITIES

- A. Duty to Comply. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity, which may result in noncompliance with permit requirements.
- B. Penalties for Violations of Permit Conditions. The Act provides that any person who violates a permit condition implementing provisions of the Act is subject to a civil penalty not to exceed \$10,000 per day of such violation. Any person who willfully or negligently violates permit conditions or the Act is subject to a fine not exceeding \$25,000 per day of violation. Any person convicted under UCA 19-5-115(2) a second time shall be punished by a fine not exceeding \$50,000 per day. Except as provided at Part VI.G, *Bypass of Treatment Facilities* and Part VI.H, *Upset Conditions*, nothing in this permit shall be construed to relieve the permittee of the civil or criminal penalties for noncompliance.
- C. Need to Halt or Reduce Activity not a Defense. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.
- D. Duty to Mitigate. The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit, which has a reasonable likelihood of adversely affecting human health or the environment. The permittee shall also take all reasonable steps to minimize or prevent any land application in violation of this permit.
- E. Proper Operation and Maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.
- F. Removed Substances. Collected screening, grit, solids, sludge, or other pollutants removed in the course of treatment shall be disposed of in such a manner so as to prevent any pollutant from entering any waters of the state or creating a health hazard. Sludge/digester supernatant and filter backwash shall not directly enter either the final effluent or waters of the state by any other direct route.
- G. Bypass of Treatment Facilities.
1. Bypass Not Exceeding Limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to paragraph 2 and 3 of this section.
 2. Prohibition of Bypass.
 - a. Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:

PART VI
DISCHARGE PERMIT NO. UT0021920

- (1) Bypass was unavoidable to prevent loss of human life, personal injury, or severe property damage;
 - (2) There were no feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance, and
 - (3) The permittee submitted notices as required under *section VI.G.3.*
- b. The Director may approve an anticipated bypass, after considering its adverse effects, if the Director determines that it will meet the three conditions listed in *sections VI.G.2.a (1), (2) and (3).*
3. Notice.
- a. *Anticipated bypass.* Except as provided above in *section VI.G.2* and below in *section VI.G.3.b*, if the permittee knows in advance of the need for a bypass, it shall submit prior notice, at least ninety days before the date of bypass. The prior notice shall include the following unless otherwise waived by the Director:
 - (1) Evaluation of alternative to bypass, including cost-benefit analysis containing an assessment of anticipated resource damages;
 - (2) A specific bypass plan describing the work to be performed including scheduled dates and times. The permittee must notify the Director in advance of any changes to the bypass schedule;
 - (3) Description of specific measures to be taken to minimize environmental and public health impacts;
 - (4) A notification plan sufficient to alert all downstream users, the public and others reasonably expected to be impacted by the bypass;
 - (5) A water quality assessment plan to include sufficient monitoring of the receiving water before, during and following the bypass to enable evaluation of public health risks and environmental impacts; and,
 - (6) Any additional information requested by the Director.
 - b. *Emergency Bypass.* Where ninety days advance notice is not possible, the permittee must notify the Director, and the Director of the Department of Natural Resources, as soon as it becomes aware of the need to bypass and provide to the Director the information in *section VI.G.3.a.(1) through (6)* to the extent practicable.
 - c. *Unanticipated bypass.* The permittee shall submit notice of an unanticipated bypass to the Director as required under *Part IV.H, Twenty Four Hour Reporting.* The permittee shall also immediately notify the Director of the Department of Natural Resources, the public and downstream users and shall implement measures to minimize impacts to public health and environment to the extent practicable.

H. Upset Conditions.

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with technology based permit effluent limitations if the requirements of paragraph 2 of this section are met. Director's administrative determination regarding a claim of upset cannot be judiciously challenged by the permittee until such time as an action is initiated for noncompliance.
2. Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - a. An upset occurred and that the permittee can identify the cause(s) of the upset;
 - b. The permitted facility was at the time being properly operated;
 - c. The permittee submitted notice of the upset as required under *Part V.H, Twenty-four Hour Notice of Noncompliance Reporting*; and,
 - d. The permittee complied with any remedial measures required under *Part VI.D, Duty to Mitigate*.
3. Burden of proof. In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

VII. GENERAL REQUIREMENTS

- A. Planned Changes. The permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when the alteration or addition could significantly change the nature or increase the quantity of parameters discharged or pollutant sold or given away. This notification applies to pollutants, which are not subject to effluent limitations in the permit. In addition, if there are any planned substantial changes to the permittee's existing sludge facilities or their manner of operation or to current sludge management practices of storage and disposal, the permittee shall give notice to the Director of any planned changes at least 30 days prior to their implementation.
- B. Anticipated Noncompliance. The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity, which may result in noncompliance with permit requirements.
- C. Permit Actions. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.
- D. Duty to Reapply. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee shall apply for and obtain a new permit. The application shall be submitted at least 180 days before the expiration date of this permit.
- E. Duty to Provide Information. The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.
- F. Other Information. When the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or any report to the Director, it shall promptly submit such facts or information.
- G. Signatory Requirements. All applications, reports or information submitted to the Director shall be signed and certified.
1. All permit applications shall be signed by either a principal executive officer or ranking elected official.
 2. All reports required by the permit and other information requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described above and submitted to the Director, and,
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position

PART VII
DISCHARGE PERMIT NO. UT0021920

having overall responsibility for environmental matters. A duly authorized representative may thus be either a named individual or any individual occupying a named position.

3. Changes to authorization. If an authorization under *paragraph VII.G.2* is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of *paragraph VII.G.2* must be submitted to the Director prior to or together with any reports, information, or applications to be signed by an authorized representative.
4. Certification. Any person signing a document under this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

- H. Penalties for Falsification of Reports. The *Act* provides that any person who knowingly makes any false statement, representation, or certification in any record or other document submitted or required to be maintained under this permit, including monitoring reports or reports of compliance or noncompliance shall, upon conviction be punished by a fine of not more than \$10,000.00 per violation, or by imprisonment for not more than six months per violation, or by both.
- I. Availability of Reports. Except for data determined to be confidential under *UAC R317-8-3.2*, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the office of Director. As required by the *Act*, permit applications, permits and effluent data shall not be considered confidential.
- J. Oil and Hazardous Substance Liability. Nothing in this permit shall be construed to preclude the permittee of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under the *Act*.
- K. Property Rights. The issuance of this permit does not convey any property rights of any sort, or any exclusive privileges, nor does it authorize any injury to private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
- L. Severability. The provisions of this permit are severable, and if any provisions of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.
- M. Transfers. This permit may be automatically transferred to a new permittee if:
 1. The current permittee notifies the Director at least 20 days in advance of the proposed transfer date;

PART VII
DISCHARGE PERMIT NO. UT0021920

2. The notice includes a written agreement between the existing and new permittee's containing a specific date for transfer of permit responsibility, coverage, and liability between them; and,
 3. The Director does not notify the existing permittee and the proposed new permittee of his or her intent to modify, or revoke and reissue the permit. If this notice is not received, the transfer is effective on the date specified in the agreement mentioned in paragraph 2 above.
- N. State or Federal Laws. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable state law or regulation under authority preserved by *UCA 19-5-117* and *Section 510* of the *Act* or any applicable Federal or State transportation regulations, such as but not limited to the Department of Transportation regulations.
- O. Water Quality - Reopener Provision. This permit may be reopened and modified (following proper administrative procedures) to include the appropriate effluent limitations and compliance schedule, if necessary, if one or more of the following events occurs:
1. Water Quality Standards for the receiving water(s) to which the permittee discharges are modified in such a manner as to require different effluent limits than contained in this permit.
 2. A final wasteload allocation is developed and approved by the State and/or EPA for incorporation in this permit.
 3. Revisions to the current CWA § 208 areawide treatment management plans or promulgations/revisions to TMDLs (40 CFR 130.7) approved by the EPA and adopted by DWQ which calls for different effluent limitations than contained in this permit.
- P. Biosolids – Reopener Provision. This permit may be reopened and modified (following proper administrative procedures) to include the appropriate biosolids limitations (and compliance schedule, if necessary), management practices, other appropriate requirements to protect public health and the environment, or if there have been substantial changes (or such changes are planned) in biosolids use or disposal practices; applicable management practices or numerical limitations for pollutants in biosolids have been promulgated which are more stringent than the requirements in this permit; and/or it has been determined that the permittees biosolids use or land application practices do not comply with existing applicable state of federal regulations.
- Q. Toxicity Limitation - Reopener Provision. This permit may be reopened and modified (following proper administrative procedures) to include, whole effluent toxicity (WET) limitations, a compliance date, a compliance schedule, a change in the whole effluent toxicity (biomonitoring) protocol, additional or modified numerical limitations, or any other conditions related to the control of toxicants if one or more of the following events occur;
1. Toxicity is detected, as per *Part I.C.1* or *Part I.C.4.a* of this permit, during the duration of this permit.

PART VII
DISCHARGE PERMIT NO. UT0021920

2. The TRE results indicate that the toxicant(s) represent pollutant(s) or pollutant parameter(s) that may be controlled with specific numerical limits, and the Director concludes that numerical controls are appropriate.
 3. Following the implementation of numerical control(s) of toxicant(s), the Director agrees that a modified biomonitoring protocol is necessary to compensate for those toxicants that are controlled numerically.
 4. The TRE reveals other unique conditions or characteristics, which in the opinion of the permit issuing authority justify the incorporation of unanticipated special conditions in the permit.
- R. Storm Water-Reopener Provision. At any time during the duration (life) of this permit, this permit may be reopened and modified (following proper administrative procedures) as per *UAC R317.8*, to include, any applicable storm water provisions and requirements, a storm water pollution prevention plan, a compliance schedule, a compliance date, monitoring and/or reporting requirements, or any other conditions related to the control of storm water discharges to "waters-of-State".

VIII. DEFINITIONS

A. Wastewater.

1. The "7-day (and weekly) average", other than for *E. coli* bacteria, fecal coliform bacteria, and total coliform bacteria, is the arithmetic average of all samples collected during a consecutive 7-day period or calendar week, whichever is applicable. Geometric means shall be calculated for *E. coli* bacteria, fecal coliform bacteria, and total coliform bacteria. The 7-day and weekly averages are applicable only to those effluent characteristics for which there are 7-day average effluent limitations. The calendar week, which begins on Sunday and ends on Saturday, shall be used for purposes of reporting self-monitoring data on discharge monitoring report forms. Weekly averages shall be calculated for all calendar weeks with Saturdays in the month. If a calendar week overlaps two months (i.e., the Sunday is in one month and the Saturday in the following month), the weekly average calculated for that calendar week shall be included in the data for the month that contains Saturday.
2. The "30-day (and monthly) average," other than for *E. coli* bacteria, fecal coliform bacteria and total coliform bacteria, is the arithmetic average of all samples collected during a consecutive 30-day period or calendar month, whichever is applicable. Geometric means shall be calculated for *E. coli* bacteria, fecal coliform bacteria and total coliform bacteria. The calendar month shall be used for purposes of reporting self-monitoring data on discharge monitoring report forms.
3. "Act," means the *Utah Water Quality Act*.
4. "Acute toxicity" occurs when 50 percent or more mortality is observed for either test species at any effluent concentration (lethal concentration or "LC₅₀").
5. "Annual Loading Cap" is the highest allowable phosphorus loading discharged over a calendar year, calculated as the sum of all the monthly loading discharges measured during a calendar year divided by the number of monthly discharges measured during that year.
6. "Bypass," means the diversion of waste streams from any portion of a treatment facility.
7. "Chronic toxicity" occurs when the IC₂₅ >90% effluent (Summer), >79% effluent (Fall), >74% effluent (Winter) and >92% effluent (Spring). The % effluent is the concentration of the effluent in the receiving water, at the end of the mixing zone expressed as per cent effluent.
8. "IC₂₅" is the concentration of toxicant (given in % effluent) that would cause a 25% reduction in mean young per female, or a 25% reduction in overall growth for the test population.
9. "Composite Samples" shall be flow proportioned. The composite sample shall, as a minimum, contain at least four (4) samples collected over the compositing period. Unless otherwise specified, the time between the collection of the first sample and the last sample shall not be less than six (6) hours nor more than 24 hours. Acceptable methods for preparation of composite samples are as follows:

PART VIII
DISCHARGE PERMIT NO. UT0021920

- a. Constant time interval between samples, sample volume proportional to flow rate at time of sampling;
 - b. Constant time interval between samples, sample volume proportional to total flow (volume) since last sample. For the first sample, the flow rate at the time the sample was collected may be used;
 - c. Constant sample volume, time interval between samples proportional to flow (i.e., sample taken every "X" gallons of flow); and,
 - d. Continuous sample volume, with sample collection rate proportional to flow rate.
10. "CWA" means *The Federal Water Pollution Control Act*, as amended, by *The Clean Water Act of 1987*.
 11. "Daily Maximum" (Daily Max.) is the maximum value allowable in any single sample or instantaneous measurement.
 12. "EPA," means the United States Environmental Protection Agency.
 13. "Director," means Director of the Division of Water Quality.
 14. A "grab" sample, for monitoring requirements, is defined as a single "dip and take" sample collected at a representative point in the discharge stream.
 15. An "instantaneous" measurement, for monitoring requirements, is defined as a single reading, observation, or measurement.
 16. "Severe Property Damage," means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
 17. "Upset," means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventative maintenance, or careless or improper operation.