



State of Utah

GARY R. HERBERT  
Governor

SPENCER J. COX  
Lieutenant Governor

Department of  
Environmental Quality

L. Scott Baird  
Executive Director

DIVISION OF WATER QUALITY  
Erica Brown Gaddis, PhD  
Director

June 16, 2020

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO RENEW A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME:	Plain City Corporation
MAILING ADDRESS:	4160 West 2200 North, Plain City, UT 84404
TELEPHONE NUMBER:	(901) 731-4908
FACILITY LOCATION:	4160 West 2200 North, Plain City, UT 84404
UPDES PERMIT NO.:	UT0021326
PERMITTED OUTFALLS:	001
RECEIVING WATER:	Unnamed drainage ditch, Dix Creek, First Salt Creek, Harold S. Crane Waterfowl Management Area and Willard Spur of the Great Salt Lake

**BACKGROUND**

This facultative lagoon sewer system was built and came into operation in 1970 and serves the community of Plain City which is located west of Ogden in Weber County. The treatment facility consists of a comminutor, followed by a six cell facultative lagoon system with two primary cells and a total surface area of 35 acres. Disinfection is accomplished with chlorination that includes three concrete tanks that serve as mixing basins. A V-notch weir is at the outfall of the basins and is used to measure the flow. The maximum daily design discharge is 0.9 MGD and the maximum monthly design discharge is 0.6 MGD for the facility. Plain City has a population of approximately 7,000 people.

**PUBLIC COMMENTS**

Public comments are invited any time prior to the deadline of the close of business on **July 16, 2020**. Written public comments can be submitted to: Danielle Lenz, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [dlenz@utah.gov](mailto:dlenz@utah.gov). After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it.

The permit is available for public review under "Public Participation" at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Danielle Lenz at 801-536-4318.

DWQ-2020-012765