



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Kimberly D. Shelley
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

October 19, 2021

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO RENEW A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME:	South Davis Sewer District South Treatment Plant
MAILING ADDRESS:	PO Box 140111, Salt Lake City, UT 84114-4870
TELEPHONE NUMBER:	(801) 580-3889
FACILITY LOCATION:	1380 West Center Street, North Salt Lake City, UT 84054
UPDES PERMIT NO.:	UT0021628
PERMITTED OUTFALLS:	001
RECEIVING WATER:	Jordan River

BACKGROUND

The South Davis Sewer District South Treatment Plant (SDSDS) serves the cities of North Salt Lake, Woods Cross and a portion of Bountiful with a daily average design flow of 4 million gallons per day (MGD) and a design population equivalent of 27,000. The facility functions utilizing a two-stage trickling filter mode, followed by a moving bed bioreactor (scheduled to be complete March 2022). The facility is located in North Salt Lake City, Davis County, with Outfall 001 which discharges to the Jordan River at latitude 40° 50' 33" and longitude 111° 56'30" and STORET Number 499181.

PUBLIC COMMENTS

Public comments are invited any time prior to the deadline of the close of business on **November 19, 2021**. A public hearing can be requested, although must be filed during the comment period. Written public comments can be submitted to: Danielle Lenz, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: dlenz@utah.gov. After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it.

The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Danielle Lenz at (385) 363-8250.

DWQ-2021-021882