



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
John Mackey, P.E.  
Director

September 26, 2023

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO MODIFY A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO MODIFY A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER THE AUTHORITY OF THE UTAH WATER QUALITY ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME:	South Davis Sewer District
FACILITY:	South Davis Sewer District North Treatment Plant
MAILING ADDRESS:	PO Box 140111, Salt Lake City, UT 84114-4870
TELEPHONE NUMBER:	(801) 580-3889
FACILITY LOCATION:	1800 West 1200 North, West Bountiful, UT 84087
UPDES PERMIT NO.:	UT0021636
PERMITTED OUTFALLS:	001
RECEIVING WATER:	State Canal to the Farmington Bay Waterfowl Management Area

**BACKGROUND**

The SDSD North Treatment Plant serves the cities of Centerville, Woods Cross, West Bountiful, and portions of Bountiful with a daily average design flow of 12 million gallons per day (MGD) and a design population equivalent of 75,000. The current UPDES permit was issued on October 1, 2022, expiring at midnight on December 8, 2026. In April 2023, by request of SDSD, the Division of Water Quality ran a Wasteload Analysis (WLA) (DWQ-2023-005597) for the SDSD North Plant that incorporated site-specific chronic ammonia criteria with mussels absent. This WLA produced relaxed limits for ammonia, specifically in regard to the maximum monthly limits, which have been incorporated into this modification. This modification does not change the daily maximum limits currently in the permit.

**PUBLIC COMMENTS**

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12. Public comments are invited any time prior to the deadline of the close of business on **October 26, 2023**. Written public comments can be submitted to: Danielle Lenz, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [dlenz@utah.gov](mailto:dlenz@utah.gov).

Page 2

South Davis Sewer District North Treatment Plant  
Public Notice

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under “Public Participation” at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Danielle Lenz at (385) 363-8250.

DWQ-2023-121080