



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Kimberly D. Shelley
Executive Director

DIVISION OF WATER QUALITY
Erica Brown Gaddis, PhD
Director

December 9, 2021

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO REISSUE A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO REISSUE A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Spanish Fork Wastewater Treatment Plant
MAILING ADDRESS: 40 South Main Street, Spanish Fork, Utah 84660
TELEPHONE NUMBER: (801) 798-5000
UPDES PERMIT NO.: UT0020109
PERMITTED OUTFALLS Outfalls 001, Outfall 001R
RECEIVING WATERS: Dry Creek, Utah Lake (Provo Bay).

BACKGROUND

The Spanish Fork Wastewater Treatment Plant (Spanish Fork) is located at 2160 North 150 East, Spanish Fork, Utah and serves the City of Spanish Fork with the outfall located at latitude 40°08'43" and longitude 11°35'54". The State of Utah Database Storet number is 499602. The current design flow of the facility is 5.0 MGD average daily flow with a peak flow of 10.4 MGD. The permit renewal includes new limits for WET testing, Cadmium and Cyanide as well as compliance schedule items for ammonia optimization and compliance with Phosphorous requirements. The plant is also increasing its maximum monthly average flow rate from 5 MGD to 8 MGD.

The facility is planning an upgrade, but the final details of that plant have not been finalized.

PUBLIC COMMENTS

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the

Page 2
Spanish Fork City
Permit UT0020109
Public Notice

issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12. Public comments are invited any time prior to the deadline of the close of business on **January 10, 2022**. Written public comments can be submitted to: Lonnie Shull, UPDES Surface Water Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: lshull@utah.gov . After considering public comment the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under “Public Notices” at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Lonnie Shull at 801-536-4394.

DWQ-2021-030466