



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Kimberly D. Shelley
Executive Director

DIVISION OF WATER QUALITY
John Mackey, P.E.
Director

February 8, 2024

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO RENEW A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME:	Coalville City
FACILITY NAME:	Coalville City Corporation Wastewater Treatment Facility
MAILING ADDRESS:	PO Box 188, Coalville, UT 84017
TELEPHONE NUMBER:	435-513-5784
FACILITY LOCATION:	63 West 100 North, Coalville, UT 84107
UPDES PERMIT NO.:	UT0025976
BIOSOLIDS PERMIT NO.:	UTL-025976
PERMITTED OUTFALLS:	001
OUTFALL LOCATION:	Latitude 40°55'13" and Longitude 111°24'09"
RECEIVING WATER:	Unnamed tributary of Chalk Creek

BACKGROUND

The Coalville City Wastewater Treatment Plant (CWWT) is located at 50 West 100 North, Coalville, Summit County, Utah. The facility serves the City of Coalville with the outfall located at the latitude 40°55'13 and longitude 111°24'09. The facility has a maximum monthly design flow of 0.58 MGD with an average daily flow rate of 0.32 MGD.

The facility consists of screening and grit removal, two parallel Modified Luzack Ettinger (MLE) process trains, two secondary clarifiers and UB disinfection prior to discharge to an unnamed tributary to Chalk Creek in the Upper Weber River watershed. Biosolids are hauled to an off-site located facility located at the Three Mile Canyon Landfill.

PUBLIC COMMENTS

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12.

Public comments are invited any time prior to the deadline of the close of business on **March 8, 2024**. Written public comments can be submitted to: Jennifer Berjikian, UPDES Individual Permits Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: wqcomments@utah.gov.

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Jennifer Berjikian at (385) 341-0272.