



State of Utah

SPENCER J. COX  
Governor

DEIDRE HENDERSON  
Lieutenant Governor

Department of  
Environmental Quality

Kimberly D. Shelley  
Executive Director

DIVISION OF WATER QUALITY  
John K. Mackey, P.E.  
Director

April 3, 2024

DIVISION OF WATER QUALITY  
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY  
PUBLIC NOTICE TO RENEW A UPDES PERMIT

**PURPOSE OF PUBLIC NOTICE**

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

**PERMIT INFORMATION**

PERMITTEE NAME: City of Tremonton  
FACILITY NAME: Tremonton Wastewater Treatment Plant  
MAILING ADDRESS: 102 South Tremonton Street  
Tremonton, Utah 84337  
TELEPHONE NUMBER: (435) 257-2674  
FACILITY LOCATION: 300 East 1200 South  
Tremonton, Utah  
UPDES PERMIT NO.: UT0020303, UTL020303  
PERMITTED OUTFALLS: 001  
OUTFALL LOCATION: Latitude 40° 41' 55" and Longitude 112° 19' 42.38"  
RECEIVING WATER: Malad River

**BACKGROUND**

Tremonton Wastewater Treatment Plant (TWWTP) has a design flow rate of 2.0 million gallons per day and currently serves the City of Tremonton in Box Elder County, Utah. The TWWTP facility's domestic waste water flow process is as follows: influent head works with micro-screen and grit filter, a primary clarifier, two aerator basins containing four aerators each, two secondary clarifiers operated in parallel, and ultra-violet disinfection prior to any discharges. The discharging outfall into the Malad River is located on site at latitude 40° 41' 55" and longitude 112° 19' 42.38". The permit also includes Biosolids.

**PUBLIC COMMENTS**

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12.

Page 2  
Public Notice

Public comments are invited any time prior to the deadline of the close of business on **May 3, 2024**. Written public comments can be submitted to: Daniel Griffin, UPDES Individual Permit Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: [wqcomments@utah.gov](mailto:wqcomments@utah.gov).

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under "Public Participation" at [www.waterquality.utah.gov/](http://www.waterquality.utah.gov/). If internet access is not available, a copy may be obtained by calling Daniel Griffin at (801) 536-4387.

DWQ-2024-001140