

Official Draft Public Notice Version **March 06, 2024**

The findings, determinations, and assertions contained in this document are not final and subject to change following the public comment period.

**FACT SHEET AND STATEMENT OF BASIS  
PITMAN FAMILY FARMS, INC.  
UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES)  
UPDES DISCHARGE PERMIT MODIFICATION  
UPDES PERMIT NUMBER: UT0020222  
UPDES BIOSOLIDS PERMIT NUMBER: UTL-020222  
MAJOR MUNICIPAL FACILITY**

**FACILITY CONTACTS**

Person Name: Mike Vance  
Position: Vice President of Turkey  
Operations and Sales  
Phone Number: (435) 436-8211

Person Name: Jay Jackson  
Position: Operator  
Phone Number: (435) 436-8211

Facility Name: Moroni City Wastewater Treatment Plant  
Permitee: Pitman Family Farms, Inc.  
Mailing Address: PO Box 308  
Moroni, UT 84646  
Telephone: (435) 436-8211  
Actual Address: 350 South 300 West  
Moroni, UT 84646

**DESCRIPTION OF FACILITY**

The Pitman Family Farms, Inc.'s current UPDES Permit No. UT0020222 for the operation of the Moroni Wastewater Treatment Plant was issued on October 16, 2023. The permit has been modified to remove the Maximum Weekly Average Dissolved Oxygen (DO) effluent limitation. The permit will continue to have Daily Minimum DO requirements, which accurately reflects the Wasteload Analysis for the facility.

The modification is reflected below, in Part I.C.2.a. of the permit.

Effluent Limitation Modification		
Parameter	Current	Updated
	Maximum Weekly Avg	Maximum Weekly Avg
Dissolved Oxygen, mg/L	5.5	No limit

The change listed above is the only change being proposed with this permit modification that is subject to public comment during the public notice period. All other permit effluent limitations remain unopened and unchanged as appropriate.

### **PERMIT DURATION**

It is recommended that this permit be effective until the current permit is renewed.

Drafted by  
Jennifer Berjikian, Discharge Permit Writer  
Utah Division of Water Quality, (801) 536-4300

### **PUBLIC NOTICE INFORMATION**

Began: Month Day, Year

Ended: Month Day, Year

Comments will be received at: 195 North 1950 West  
PO Box 144870  
Salt Lake City, UT 84114-4870

The Public Notice of the draft permit was published on the Division of Water Quality webpage.

During the public comment period provided under R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing, if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in R317-8-6.12.

### **ADDENDUM TO FSSOB**

#### **Responsiveness Summary**