



State of Utah

SPENCER J. COX
Governor

DEIDRE HENDERSON
Lieutenant Governor

Department of
Environmental Quality

Kimberly D. Shelley
Executive Director

DIVISION OF WATER QUALITY
John Mackey, P.E.
Director

April 2, 2024

DIVISION OF WATER QUALITY
UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY
PUBLIC NOTICE TO RENEW A UPDES PERMIT

PURPOSE OF PUBLIC NOTICE

THE PURPOSE OF THIS PUBLIC NOTICE IS TO DECLARE THE STATE OF UTAH'S INTENTION TO RENEW A UTAH POLLUTANT DISCHARGE ELIMINATION SYSTEM (UPDES) PERMIT UNDER AUTHORITY OF THE UTAH WATER POLLUTION CONTROL ACT, SECTION 19-5-104(9) AND 107(2), UTAH CODE ANNOTATED 1953, AS AMENDED. SAID "PERMIT" REFERS TO THE UPDES PERMIT AND THE FACT SHEET STATEMENT OF BASIS (INCLUDING TOTAL MAXIMUM DAILY LOADS (TMDL'S)) IF APPLICABLE, AS PER SECTION 303(D) OF THE FEDERAL CLEAN WATER ACT (CWA)].

PERMIT INFORMATION

PERMITTEE NAME: Intermountain Concrete Company
FACILITY NAME: Intermountain Concrete
MAILING ADDRESS: 625 East Main Street
Vernal, Utah 84078
TELEPHONE NUMBER: (435) 789-0774
FACILITY LOCATION: Highway 40, Jensen, UT
UPDES PERMIT NO.: UT0024015
PERMITTED OUTFALLS: 001, 002
OUTFALL LOCATION: 001: LAT 40°22' 31" and LONG 109° 20' 22"
002: LAT 40°22' 31" and LONG 109° 20' 22"
RECEIVING WATER: Green River

BACKGROUND

Intermountain Concrete Company stores, washes, and sizes gravel for use in the construction industry. Wash water is obtained from irrigation ditches and is used to clean the gravel. The makeup for the wash water is taken by water right from irrigation ditches. The makeup water then travels through three ponds known as West Pond, Middle Pond, and Main Pond. Water is pumped from the Main pond to the wash plant. After its use in the wash plant, it is discharged to the first of two settling basins. It is then transferred to a second settling basin. This water is recycled from the second settling basin back to the Main Pond. Outfall 001 drains the Main Pond from a pipe located deep in the pond. A second discharge point, Outfall 002, is located on the Main Pond to handle any excess water in the system.

PUBLIC COMMENTS

During the public comment period provided under Utah Administrative Code (UAC) R317-8-6.5, any interested person may submit written comments on the draft permit and may request a public hearing if no hearing has already been scheduled. A request for a public hearing shall be in writing and shall state the

nature of the issues proposed to be raised in the hearing. All comments will be considered in making the final decision and shall be answered as provided in UAC R317-8-6.12.

Public comments are invited any time prior to the deadline of the close of business on **May 2, 2024**. Written public comments can be submitted to: Lonnie Shull, UPDES Individual Permits Section, Utah Division of Water Quality, PO Box 144870, Salt Lake City, Utah 84114-4870 or by email at: lshull@utah.gov or wqcomments@utah.gov.

After considering public comments, the Utah Division of Water Quality may execute the permit issuance, revise it, or abandon it. The permit is available for public review under "Public Participation" at www.waterquality.utah.gov/. If internet access is not available, a copy may be obtained by calling Lonnie Shull at (801) 536-4394.

DWQ-2024-001818